Right choice for ultimate yield

LSIS strives to maximize customers' profit in gratitude of choosing us for your partner.

Programmable Logic Controller

Dnet I/F Module

XGT Series

User's Manual

XGL-DMEA





Safety Instructions

- Read this manual carefully before installing, wiring, operating, servicing or inspecting this equipment.
- Keep this manual within easy reach for quick reference.



Before using the product ...

For your safety and effective operation, please read the safety instructions thoroughly before using the product.

- Safety Instructions should always be observed in order to prevent accident or risk by using the product properly and safely.
- Precautious measures can be categorized as "Warning" and "Caution", and each of the meanings is as follows.



This symbol indicates the possibility of serious injury or death if some applicable instruction is violated



This symbol indicates the possibility of severe or slight injury, and damages in products if some applicable instruction is violated

Moreover, even classified events under its caution category may develop into serious accidents depending on situations. Therefore we strongly advise users to observe all precautions in a proper way just like warnings.

► The marks displayed on the product and in the user's manual have the following meanings.



/! Be careful! Danger may be expected.



/\sqrt{\text{ Be careful! Electric shock may occur.}

After reading this user's manual, it should be stored in a place that is visible to product users.

Safety Instructions for design process

Warning

- Please install a protection circuit on the exterior of PLC so that the whole system may operate safely regardless of failures from external power or PLC. Any abnormal output or operation from PLC may cause serious problems to safety in whole system.
 - Install protection units on the exterior of PLC like an interlock circuit that deals with opposite operations such as emergency stop, protection circuit, and forward/reverse rotation or install an interlock circuit that deals with high/low limit under its position controls.
 - If any system error (watch-dog timer error, module installation error, etc.) is detected during CPU operation in PLC, all output signals are designed to be turned off and stopped for safety. However, there are cases when output signals remain active due to device failures in Relay and TR which can't be detected. Thus, you are recommended to install an addition circuit to monitor the output status for those critical outputs which may cause significant problems.
- Never overload more than rated current of output module nor allow to have a short circuit. Over current for a long period time may cause a fire.
- Never let the external power of the output circuit to be on earlier than PLC power, which may cause accidents from abnormal output or operation.
- Please install interlock circuits in the sequence program for safe operations in the system when exchange data with PLC or modify operation modes using a computer or other external equipments Read specific instructions thoroughly when conducting control operations with PLC.

Safety Instructions for design process

 I/O signal or communication line shall be wired at least 100mm away from a high-voltage cable or power line. Fail to follow this instruction may cause malfunctions from noise

Safety Instructions on installation process

- ▶ Use PLC only in the environment specified in PLC manual or general standard of data sheet. If not, electric shock, fire, abnormal operation of the product may be caused.
- ▶ Before install or remove the module, be sure PLC power is off. If not, electric shock or damage on the product may be caused.
- ▶ Be sure that every module is securely attached after adding a module or an extension connector. If the product is installed loosely or incorrectly, abnormal operation, error or dropping may be caused. In addition, contact failures under poor cable installation will be causing malfunctions as well.
- ▶ Be sure that screws get tighten securely under vibrating environments. Fail to do so will put the product under direct vibrations which will cause electric shock, fire and abnormal operation.
- ▶ Do not come in contact with conducting parts in each module, which may cause electric shock, malfunctions or abnormal operation.

Safety Instructions for wiring process

Warning

- Prior to wiring works, make sure that every power is turned off. If not, electric shock or damage on the product may be caused.
- After wiring process is done, make sure that terminal covers are installed properly before its use. Fail to install the cover may cause electric shocks.

∴ Caution

- ▶ Check rated voltages and terminal arrangements in each product prior to its wiring process. Applying incorrect voltages other than rated voltages and misarrangement among terminals may cause fire or malfunctions.
- ▶ Secure terminal screws tightly applying with specified torque. If the screws get loose, short circuit, fire or abnormal operation may be caused. Securing screws too tightly will cause damages to the module or malfunctions, short circuit, and dropping.
- ▶ Be sure to earth to the ground using Class 3 wires for FG terminals which is exclusively used for PLC. If the terminals not grounded correctly, abnormal operation or electric shock may be caused.
- ▶ Don't let any foreign materials such as wiring waste inside the module while wiring, which may cause fire, damage on the product or abnormal operation.
- Make sure that pressed terminals get tighten following the specified torque. External connector type shall be pressed or soldered using proper equipments.

Safety Instructions for test-operation and maintenance

Warning

- ▶ Don't touch the terminal when powered. Electric shock or abnormal operation may occur.
- Prior to cleaning or tightening the terminal screws, let all the external power off including PLC power. If not, electric shock or abnormal operation may occur.
- ▶ Don't let the battery recharged, disassembled, heated, short or soldered. Heat, explosion or ignition may cause injuries or fire.

∴ Caution

- ▶ Do not make modifications or disassemble each module. Fire, electric shock or abnormal operation may occur.
- Prior to installing or disassembling the module, let all the external power off including PLC power. If not, electric shock or abnormal operation may occur.
- Keep any wireless equipment such as walkie-talkie or cell phones at least 30cm away from PLC. If not, abnormal operation may be caused.
- When making a modification on programs or using run to modify functions under PLC operations, read and comprehend all contents in the manual fully. Mismanagement will cause damages to products and accidents.
- Avoid any physical impact to the battery and prevent it from dropping as well. Damages to battery may cause leakage from its fluid. When battery was dropped or exposed under strong impact, never reuse the battery again. Moreover skilled workers are needed when exchanging batteries.

Safety Instructions for waste disposal

△ Caution

▶ Product or battery waste shall be processed as industrial waste.

The waste may discharge toxic materials or explode itself.

Revision History

Version	Date	Remark	Page
V1.0	'05.03	First edition	-
V1.1	'05.05	Function description added	A-17
V1.2	'05.07	O/S version up description added (V1.0 → V1.1) 1) Data latch/clear function added 2)SyCon master setting changed "Handshake of the process data" setting No consistence, uncontrolled → Buffered, host controlled	5-14,6-6 7-3,7-18
V1.3	'05.11	Revision of content	
V1.4	'06.06	Added Extendable Smart I/O Dnet I/F adapter.	1-5, 7-16 ~ 7-28
V1.5	'07.03	Updated Sycon mode setting by Smart I/O Upgrade	A-17 ~ A-19
V1.6	'08.12	Added contents related with XGR Changed address of headquarter	1-3
V1.7	'11.05	How to enable link through flag added	6-5

^{*} The number of User's manual is indicated right part of the back cover.

[©] LSIS Co., Ltd 2005

Table of Contents

Chap	oter 1 Introduction	1-1 ~ 1-5
	1.1 What is DeviceNet? 1.2 Characteristics of the module 1.3 Information for Module Operation 1.4 Configuration of Smart I/O for Dnet	
Chap	oter 2 Specifications	2-1 ~ 2-8
	2.1 General Specifications 2.2 Performance Specifications 2.3 Part names and structure 2.4 Cable Specifications 2.5 Terminating Resistor 2.6 Tap/Divider	2-2 2-4 2-5 2-6
Chap	oter 3 Installation and Test Operation	3-1 ~ 3-8
	3.1 Installation 3.1.1 Precautions for installation 3.1.2 Materials required for installation 3.1.3 Installation 3.2 From Setting to Operation 3.3 Setting Procedure of Sycon and XG-PD.	3-1 3-1 3-2 3-7
Chap	oter 4 System Configuration	4-1 ~ 4-3
	4.1 System with LS Dnet I/F module used	ther manufacturers 4-2
Chap	oter 5 SyCon Setting	5-1 ~ 5-27
	5.1 SyCon S/W Environment 5.1.1 SyCon S/W configuration file 5.1.2 System requirement 5.2 SyCon Program Installations 5.3 SyCon Execution 5.4 Monitoring Information in SyCon	

Chapter 6 High-speed Link Setting 6-1 ~ 6-18
6.1 Introduction 6-1 6.2 How to use XG-PD 6-2 6.3 High-speed Link Editing 6-4 6.4 Read and Write of High-speed Link 6-10 6.5 Enable Link 6-11 6.6 System Diagnosis 6-14 6.7 High-speed Link Information 6-17
Chapter 7 Communication Program
7.1 Example Program
Chapter 8 Troubleshooting8-1 ~ 8-7
8.1 Symptoms and Management by LED Status 8-1 8.2 System Diagnosis in XG-PD 8-1 8.2.1 Communication module information 8-2 8.2.2 High-speed link 8-2 8.2.3 Autoscan 8-3 8.3 Diagnosis of Communication Module through XG5000 8-4 8.4 Troubleshooting of Respective Errors 8-5 8.4.1 SyCon communication error 8-5 8.4.2 XG-PD abnormal connection 8-6 8.4.3 Communication error with slave module 8-7
Appendix A-1 ~ A-21
A.1 List of Flags A-1 A.1.1 Special relays A-1 A.1.2 Special Register for Data Link A-9 A.2 Terminology A-11 A.3 Smart I/O Mode Setting in SyCon A-18 A.4 External Dimensions A-21

Chapter 1 Introduction

1.1 What is DeviceNet?

DeviceNet was developed in response to the request for replacing expensive analog 4~20mA standard with a single digital standard, which is used as a communication link to connect various industrial devices of limit switch, photo-electronic sensor, motor controller, inverter, bar code reader and panel display to the network.

CAN (Controller Area Network) developed by BOSCH was set to substitute low-priced network cable for expensive Wire Harness of automobiles for the European automobile market. It is composed of Physical Layer and Data Link Layer only. As of now, it is proposed as ISO 11898 and 11591-1 standards. Since CAN application fields require services that are beyond the basic function specified in the data link layer, research on Application Layer has been ongoing. The key results are CAL (CAN Application Layer), SDS(Smart Distributed System), DeviceNet and CAN Kingdom certified by CiA (CAN in Automation).

DeviceNet is an Application Layer developed by Rockwell/Allen-Bradley, widely used in the present industrial automation field. These compatibility characteristics are similar to other network systems. However there are few network systems that guarantee their compatibilities. It is because there is no test to check compatibility with other company's products and due to high costs for this kind of test. Thus ODVA (Open DeviceNet Vendor Association), which supports all the services of Device Net, has solved these problems through research institutes of universities and technical research institutes in USA, Japan and UK. Since DeviceNet uses CAN communication protocol, low-priced CAN micro chip applied will reduce the cost. And direct connection of master and respective devices with the network of device level is available, improving communication quality between devices. In addition, flexible counteractions against errors are also available by access to important diagnosis information of device level which was impossible to use via the I/O interface. Its application range is extended to complicated and highly-developed services (High-speed data communication between controllers, synchronization of lots of devices performing super High-speed scan, etc.).

1.2 Characteristics of the Module

DeviceNet (hereinafter referred to as Dnet) I/F module have features as follows;

- ▶ 1 master module can control 63 slave modules with the max. 28,000 points of I/O control available.
- ▶ Multi-drop and T-diverged connection is available allowing the system to be extended and changed easily with flexible system operation function provided.
- ▶ Open network available to connect with other company's various slave modules.
- ▶ Master and slave can be set through Configuration Tool (SyCon), and communication control is available through XG-PD.
- ▶ Automatic setting, in other words, Auto scan is available for the modules (which exist) in the network.
- ► Configuration Tool (SyCon)
 - 1) Station number (MAC ID) can be specified (0 ~ 63) through Configuration Tool (SyCon).
 - 2) Communication speed can be specified (125/250/500 kbps) through Configuration Tool (SyCon).
 - 3) Out of 4 communication types (Poll, Bit strobe, COS, Cyclic), one DeviceNet can be selected through Configuration Tool (SyCon).
- ▶ Setup time and installation cost of the system will be saved from reduced connections and wiring works by using a single cable for communication power(24V) and communication signal line.
- ▶ Network setting and various diagnoses can be simply arranged through SyCon and XG-PD, in other words, diagnosis of the whole network or each slave is available.
- ▶ Real-time control over I/O devices in the lowest level of the network system is available. In addition, connection to various slaves I/O is available.
 - General I/O, actuator, proximity switch, optical switch, valve, inverter, A/D module, D/A module, position control, etc.

1.3 Information for Module Operation

1) It describes required components to operate the product.

Classificatio n	Туре	Description	Reference
Series	XGL-DMEA	DeviceNet I/F module.	Master
Software	SyCon	Software for Station number, Speed, SyCon Communication methods, configuration of network setting.	
	EDS	Including module information (Product code/Type, Maker name/Maker number) - It is used to configure the network in SyCon.	-
	XG 5000	Software for PLC programming - XG-PD can be executed in XG 5000.	•
	XG-PD	Software for Send/Receive parameter setting.	Included in XG 5000

Remark

XG 5000 program can be downloaded at our company website. If you do not have an access to the internet, contact the nearest agency for CD-ROM about XG 5000. EDS file related to our slave module (Smart Link) can be downloaded at <u>Http://eng.lsis.biz</u>.

2) It describes about the number of module and position that can be installed in a single CPU module.

9				
Classification	Description			
Position	XGK/XGI	Standard base and Extension base		
POSITION	XGR	Extension base		
Number	A maximum of 12 In case of using with other communication modules, It is able to inst maximum of 24 (But High-speed link setting is limited to 12)			
High-speed link number	A maximum of 12 (It can not set for P2P)			

- 3) Please refer to below User Manuals to write communication program with Dnet I/F module.
 - XGK Instruction Manual / XGI Instruction Manual
 - XG 5000 User Manual
 - XGK CPU User Manual / XGI CPU User Manual
 - Smart I/O User Manual
 - Other company's User Manual which is related to Dnet
 - Extendable type Smart I/O User Manual

1.4 Configuration of Smart I/O for Dnet

1) Slave Products List of Stand-alone type

1) Slave Pro		Stand-alone type		
Product			- Details	
Classification	Code	Designations	Details	
	47060040	GDL-D22A(N)	DC input 16 points	
	47060097	GDL-D22A(Q)	DC input 16 points, Quick mode	
	47060039	GDL-D24A(N)	DC input 32 points	
	47060098	GDL-D24A(Q)	DC input 32 points, Quick mode	
	47060041	GDL-TR2A(N)	TR output 16 points (0.1A, Sink)	
	47060099	GDL-TR2A(Q)	TR output 16 points (0.1A, Sink), Quick mode	
	47060089	GDL-TR2A1	TR output 16 points (0.5A, Sink)	
	47060112	GDL-TR2A1(Q)	TR output 16 points (0.5A, Sink), Quick mode	
	47060062	GDL-TR2B	TR output 16 points (0.5A, Source)	
	47060103	GDL-TR2B(Q)	TR output 16 points (0.5A, Source), Quick mode	
	47060042	GDL-TR4A(N)	TR output 32 points (0.1A, Sink)	
	47060100	GDL-TR4A(Q)	TR output 32 points (0.1A, Sink), Quick mode	
Fixed type	47060080	GDL-TR4A1	TR output 32 points (0.5A, Sink)	
	47060113	GDL-TR4A1(Q)	TR output 32 points (0.5A, Sink), Quick mode	
	47060061	GDL-TR4B	TR output 32 points (0.5A, Source)	
	47060104	GDL-TR4B(Q)	TR output 32 points (0.5A, Source), Quick mode	
	47060043	GDL-DT4A(N)	DC input 16 points/TR output 16 points (0.1A, Sink)	
	47060101	GDL-DT4A(Q)	DC input 16 points/TR output 16 points (0.1A, Sink), Quick mode	
	47060082	GDL-DT4A1	DC input 16 points/TR output 16 points (0.5A, Sink)	
	47060114	GDL-DT4A1(Q)	DC input 16 points/TR output 16 points (0.5A, Sink), Quick mode	
	47060063	GDL-DT4B	DC input 16 points/TR output 16 points (0.5A, Source)	
	47060105	GDL-DT4B(Q)	DC input 16 points/TR output 16 points (0.5A,Source), Quick mode	
	47060044	GDL-RY2A(N)	Relay output 16 points	
	47060102	GDL-RY2A(Q)	Relay output 16 points, Quick mode	
	47060053	GDL-D22C	DC input 16 points	
	47060106	GDL-D22C(Q)	DC input 16 points, Quick mode	
	47060052	GDL-D24C	DC input 32 points	
	47060107	GDL-D24C(Q)	DC input 32 points, Quick mode	
	47060054	GDL-TR2C	TR output 16 points (0.5A, Source)	
	47060108	GDL-TR2C(Q)	TR output 16 points (0.5A, Source), Quick mode	
	47060087	GDL-TR2C1	TR output 16 points (0.5A, Sink)	
	47060115	GDL-TR2C1(Q)	TR output 16 points (0.5A, Sink), Quick mode	
Changeable	47060055	GDL-TR4C	TR output 32 points (0.5A, Source)	
type	47060109	GDL-TR4C(Q)	TR output 32 points (0.5A, Source), Quick mode	
	47060081	GDL-TR4C1	TR output 32 points (0.5A, Sink)	
	47060116	GDL-TR4C1(Q)	TR output 32 points (0.5A, Sink), Quick mode	
	47060056	GDL-DT4C	DC input 16 points/TR output 16 points (0.5A,Source)	
	47060110	GDL-DT4C(Q)	DC input 16 points/TR output 16 points (0.5A,Source), Quick mode	
	47060083	GDL-DT4C1	DC input 16 points/TR output 16 points (0.5A, Sink)	
	47060117	GDL-DT4C1(Q)	DC input 16 points/TR output 16 points (0.5A, Sink), Quick mode	
	47060057	GDL-RY2C	Relay output 16 points	
	47060111	GDL-RY2C(Q)	Relay output 16 points, Quick mode	

Remark

- 1) Fixed type: A product whose I/O terminal block is fixed on the module.
- 2) Changeable type: A product whose I/O terminal block can be installed or removed.
- 3) Quick mode: A product whose initializing time is 1.5 sec. after the communication power is On.

2) Slave Products List of Extendable type

	Products		
Classification	Code	Designation s	Details
Communication Adapter	47060131 XDL-BSSA		Dnet I/F Adapter
	47230004	XBE-DC32A	24VDC Input 32points
	47230010	XBE-DC16A	24VDC Input 16points
	47230011	XBE-DC08A	24VDC Input 8points
	47230006	XBE-RY16A	Relay Output 16points
Extendable I/O	47230009	XBE-RY08A	Relay Output 8points
	47230005	XBE-TN32A	Transistor Output 32points(NPN Type)
	47230013	XBE-TN16A	Transistor Output 16points(NPN Type)
	47230012	XBE-TN08A	Transistor Output 8points(NPN Type)
	47230014	XBE-DR16A	24VDC Input 9points/Relay Output 16points
	47230007	XBF-AD04A	Current/Voltage Input 4Ch
Extendable	47230008	XBF-DV04A	Voltage Output 4Ch
Special module	47230018	XBF-RD04A	RTD input 4Ch
,	47230017	XBF-DC04A	Current Output 4Ch

Smart Link List for wiring of Extendable Slave products

Smart Eink List for willing of Exterioable Glave products					
Clas	Classification		Details		
Terminal Board	Tananananananananananananananananananan	SLP-T40P	Connection method is changed from connector to terminal board(40p)		
Relay Board	THE THE PARTY OF T	SLP-RY4A	Output type is changed from Tr.(NPN type) output to relay output. Connection method is also changed from connector to terminal board(40p).		
	2	SLP-C101-XB	Expansion length 1m, Plastic Hood Type, 40p		
Connection		SLP-C201-XB	Expansion length 2m, Plastic Hood Type, 40p		
Cable		SLP-CT101-XB	Expansion length 1m, Soft Tube Type, 40p		
		S	SLP-CT201-XB	Expansion length 2m, Soft Tube Type, 40p	

Chapter 2 Specifications

2.1 General Specifications

General specifications of XGT series are as specified below in Table 2.1.

No.	Item	Specification					Related specifications			
1	Operating temp.			0°0	~+55℃		-			
2	Storage temp.			-25°	C ~ +70 ℃		-			
3	Operating humidity			5~95%RH	, no dew allowed		-			
4	Storage humidity			5∼95%RH	, no dew allowed		-			
				For discon	tinuous vibration		-			
		Frequen	су	Acceleration	Amplitude	Number				
		10≤f< 57	7 Hz	-	0.075mm					
5	Vibration	57≤f≤150	0 Hz	9.8 m/s² (1G)	-]				
5	immunity		For c	ontinuous vil	oration	Each 10 times in	IEC61131-2			
		Frequen	су	Acceleration	Amplitude	X,Y,Z directions				
		10≤f< 57	7 Hz	-	0.035mm]				
		57≤f≤150	0 Hz	4.9 m/s² (0.5G) -					
6	Impact immunity	* Authorized * Pulse way	Max. impact acceleration: 147 m/s² (15G) Authorized time: 11 ms Pulse wave : Sign half-wave pulse (Each 3 times in X,Y,Z directions)				IEC61131-2			
		Square wave impulse noise			±1,5	500V	Test specification of LS Industrial Systems			
		Static electric discharging				e : 4kV ischarging)	IEC 61131-2, IEC 61000-4-2			
7	Noise immunity		n electi field no	romagnetic ise	27 ~ 500M	Hz, 10 V/m	IEC 61131-2, IEC 61000-4-3			
					Fast Transient /burst	Class	Power module		nalog I/O tion interface	IEC 61131-2, IEC 61000-4-4
		noise Voltage		e 2kV	11	ΚV				
8	Ambient conditions		No corrosive gas or dust							
9	Operating height	2,000m or less								
10	Pollution level	2 or less								
11	Cooling type		Natural air cooling							

Table 2.1 General Specifications

Notes

[Note 1] IEC (International Electrotechnical Commission):

An international nongovernmental organization which promotes internationally cooperated standardization in electric/electronic field, publishes international standards and manages applicable estimation system related with.

[Note 2] Pollution level:

An index indicating pollution level of the operating environment which decides insulation performance of the devices. For instance, Pollution level 2 indicates the state generally that only non-conductive pollution occurs. However, this state contains temporary conduction due to dew produced.

2.2 Performance Specifications

1) Performance specifications

Performance specifications of DeviceNet (hereinafter referred to as Dnet) I/F module are as described below.

			(nereinatter referred to as Dnet) I/F module are as described below.		
	Item		Performance Specifications		
	Transmission Sp	eed (kbps)	125/250/500		
	Transmission Ty	•	Poll, Bit strobe, COS, Cyclic		
	Communication		500 (125kbps)/250 (250kbps)/100 (500kbps)		
	distance(m)	Thin Cable	100 (125/250/500kbps)		
	Terminal resista	` '	121 (1%, 1/4W)		
	Max.drop	125 kbps	6 (Max. extended length 156)		
	length(m)	250 kbps	6 (Max. extended length 78)		
		500 kbps	6 (Max. extended length 39)		
	Data Packet		0~8 Bytes		
L l	Message Access	s Control	CSMA/NBA		
Transmission	Network Structur	re	Trunk/drop line		
Specification			Power/Signal cable inside the identical network cable		
	Bus Type		Poll type		
	Max. number of	nods	Up to 64 (including master) MAC IDs (MAC Identifier)		
	System Features		Insertion and removal of nod available in voltage On status		
	Operation Voltage	ge	DC 24V		
			Module: Checks duplicated station/ Checks CRC error		
	Diagnosis Funct	ion	SyCon: Detects defective station/Checks BusOff/Auto-scan		
	J		function		
-			XG-PD: Monitors High-speed link		
	Master/Slave Op	eration	Available only in master		
			1) SyCon (CONFIG Port of Dnet I/F)		
Parameter	setting		2) Setting to High-speed link of XG-PD		
			(RS-232C of CPU module or USB port)		
	Data process un	it	Byte		
XG-PD	01/0	a art a lad	Select among 20ms, 50ms, 100ms, 200ms, 500ms, 1s, 5s and 10s		
(High-	Send/Receive pe	erioa	- Default : 20ms		
speed	Max. communica	ation point	Send 28672points, Receive 28672 points, 3584 bytes respectively		
link)	Max. block numb	per	63 (Setting range: 0~62)		
	Max. point numb	er per block	2048 points (256 bytes)		
	Max. modules in	stalled	Up to 12 (available on basic base and added base)		
Basic	Internal-consum	ed current	440		
Specification	(mA)		440		
	Weight (g)		110		

Remark

- 1) Transmission distance of Dnet I/F module is inversely proportional to data transmission rate. If thin cable is used, the transmission distance will be limited to 100m regardless of data transmission rate.
- 2) CSMA/NBA (Carrier Sense Multiple Access with Non-destructive Bitwise Arbitration)
- 3) If the station No. of Dnet I/F module (master module) is specified, surely reset the applicable slave module.

2) Communication methods

Communication methods can be set per module when it is supported by slave module.

Setting of Slave insertion/setting in SyCon is as shown below.

- (1) Automatic setting: Online → Automatic Network Scan
- (2) Manual setting: Settings → Device Configuration

Communication method's features are as shown below.

Communication method	Feature
Poll	Master and slave module Send/Receive the data by one on one.
Bit-Strobe	It is used only in input module. The way to transmit data simultaneously for master module from its input type slave modules when the master module's data transmission request is received.
COS (Change of State)	If input data status of slave module is changed, slave module transmits changed data to master module. But output type slave module, Settings → Device Configuration Menu selection → Connection Object Instance Attributes Setting window→ Expected Packet Rate Category, transmits every time according to its setting rates.
Cyclic	Slave module attempts to Send/Receive periodically. Communication period setting, Settings → Device Configuration Menu selection→ Connection Object Instance Attributes Setting window→ Expected Packet Rate Category, sent/receives data periodically between master and slave module according to its setting periods.

So, Communication method should be used with cautions along with data process of Input/Output module in the system.

3) EDS (Electronic Data Sheet) file

▶ It is to allow other vendors to use restricted information of product through EDS file format.

Restricted information of product: Maker name and unique number (ODVA Certification)

Module information (Master and slave module)


Input/Output module information (Input point, Output point)

Information on communication support method

► EDS file addition: It can be executed by File → Copy EDS.

Copied EDS file can be used only when located under EDS folder of SyCon execution directory

2.3 Part names and Structure



(1) LED display parts

LED		Status	LED display description
RUN	On	Normal	Completion of initializing.
IXOIN	Off	Error	Error is occurred.
I/F	Flickering	Normal	Normal status of interface in CPU module.
1/1	On/Off	Error	Error status of interface in CPU module.
	On	Normal	Normal status when High-speed link is enabled.
HS	Flickering	Waiting	Communication is disconnected between Dnet I/F and Slave module while downloading at High-speed link enabled status by SyCon.
	Off	Error	High-speed link service is in Critical error while High-speed link is enabled.
D-RUN	Flickering	Stop	Stop status of communication between Dnet I/F module and slave module.
	On	Communicating	Communication status of Dnet I/F module and slave module.
MNS	Off	Power Off	 Waiting status of Dnet I/F module communication. Non-completed status of Checking duplicated MAC ID on network. It is not supplied external power supply (DC24V).
	Green Flickering	Waiting	Communication waiting status between Dnet I/F module and slave. - It is recognized the information of network (Station number, ID, Communication speed) in SyCon.
	Green Flickering	Normal	Normal communication status between Dnet I/F module and slave.
	Red Flickering	Error	Slave module is separated network while communicating.
	Red Flickering	Critical error	 Dnet I/F module could not access the network. Non-ability status of Communication (Bus Off). Duplicated ID module is existed in network.

(2) RS-232C connector for SyCon connection

Dnet I/F	module	Connection number and	Computer/ Communication equipment
Pin num.	Name	signal direction	Name
1	CD		CD
2	RXD	←	RXD
3	TXD		TXD
4	DTR		DTR
5	SG		SG
6	DSR		DSR
7	RTS		RTS
8	CTS		CTS
9	RI		RI

^{*} Loader cable is common XGK CPU module and GM/MK module loader cable.

→(3) 5 pin connector (for exeternal connection)

Color	Signal	Service	5 pin connector
Red	DC 24V(+)	Vcc	121Ω
White	CAN_H	Signal wire	
Bare	Drain	Shielded wire	
Blue	CAN_L	Signal wire	↑ ↑↑↑
Black	DC 24V(-)	GND	Blue White Black Bare ^{Red}

2.4 Cable Specifications

1) Cable specifications (Belden)

y dable openinations (Beiden)					
Classification	Thick (class1)	Thick (class2)	Thin (class2)		
Туре	7897A	3082A	3084A		
Cable Type	Round			Trunk and Drop line is used	
Impedance (Ω)	120				
Temperature range (°C)	-20 ~ 75				
Max. allowable current(A)	8		2.4	concurrently	
Min. radius of curvature (in.)	4.4	4.6	2.75		
Core wire number	5 wires				

2) Maximum trasmission distance for repective cable types


(1) If one type of trunk line is used

T	Maximum distance		
Transmission speed	Thick cable	Thin cable	
125kbps	500m	100m	
250kbps	250m	100m	
500kbps	100m	100m	

(2) If mixed with trunk line

<u>/-/</u>			
Transmission speed	Max. distance if Thin and Thick cables are used as mixed		
125kbps	Thick cable length + 5 x Thin cable length ≤ 500m		
250kbps	Thick cable length + 2.5 x Thin cable length ≤ 250m		
500kbps	Thick cable length + Thin cable length ≤ 100m		

3) Structure




Signal cable (Blue/White)

- 18AWG 19X30 (Thick)
- 24AWG 19X36 (Thin)

2.5 Terminating Resistances

- Attach 121Ω , 1%, 1/4W of resistance to both ends of the network.
- Connect connector's CAN_H (White) with CAN_L (Blue) signal cable.



• Connection Connector

Classification	Cable connection method		
Classification	single direction connector	dual direction connector	
Shape			

Remark


- 1) Be sure to attach the terminating resistor to both ends of the network trunk line, or to both ends of the tap if composed of device port tap. If the terminating resistor is omitted, communication will not be normal.
- 2) If the terminating resistor is installed on the port tap, it is not necessary to install an additional terminating resistor.

2.6 Tap/Divider


1) 4-Port / 8-Port Tap (LSIS)

If you use multi tap, it is convenient to configuration and modification of network system.

(1) 4-Port tab (GDL-T4S)



(2) 8-Port tab (GDL-T8S)




Remark


- 1) Be sure to set switch for the terminating resistor which is come under both ends of the network trunk line to On. If the terminating resistor is omitted, communication will not be normal.
- 2) If you want to use multi tab two more than, don't set all switch for the terminating resistor to On. Because communication will not be normal.

2) 1-Branch (T-Branch)/3-Branch tap (Ex.: Company OMRON)


(1) 1-Branch tap (DCN-2C)



(2) 3-Branch tap (DCN-4C)



3) Multi Tab Configuration of LSIS and Other company



Chapter 3 Installation and Test Operation

3.1 Installation

3.1.1 Precautions for installation

For system configuration through Dnet I/F module, carefully make sure of the following items prior to installation.

- 1) Check the basic factors necessary for system configuration so to select an appropriate communication module.
- Prepare accessories such as cable, tap and terminating resistor used for communication module.
- 3) Speed of communication modules shall be identical respectively based on the communication speed applicably used for the communication module in compliance with cable specifications.
- 4) If the tap is used, surely apply terminating resistor to the tap of both ends.
- 5) In a single network, it must be set without duplicated station number.
- 6) Before the communication module is installed, check for any power supply, any foreign material on the base connector the module will be installed on and any damage on the connector pin of the module.
- 7) The module when installed on the base board or used solely shall be securely connected with the correspondent. If the connection is incomplete, interface with CPU may be abnormal.
- 8) Communication speed to be applied to this communication module is 125/250/500kbps. In order to change the communication speed of slave module once specified, let it powered off and then change the communication setting switch to apply the changed mode.

3.1.2 Materials necessary for installation

Materials necessary	Dnet I/F module	
Communication cable	Thick cable/Thin cable (only for Dnet)	
Тар	4,8-port tap	
Terminating resistor	Terminating resistor : 121Ω, 1%, 1/4W	
24V power supplier	General power supplier	
Connector	Open type 5-pin connector	

3.1.3 Installation


1) Precautions for installation of the connector

Prior to installation of the connector, please pay attention to the following.

- (1) Installation shall be performed when no signal and power supply is carried by cable.
- (2) If the module installed on the system operates, stop the operation prior to installation.


After the installation is complete, secure the applicable cable tightly so to keep from being vibrated or escaped.

2) How to install the connector




- (1) First, slip off the coat of the cable about 7cm to connect.
- (2) Cut the packing cover contracted about 4cm to cover on the cable and wrap up the exposed conductor and insulated coat of the cable.
- (3) Slip off the coat of the cable about 8mm at the both ends respectively and apply heat to the packing cover contracted to adhere closely to the cable.
- (4) Insert the slipped coat into the connector's clamp screw with a proper distance and tighten the screw (DC power supply and signal line is in identical cable, so ,be sure to make designation of the signal identical between cable and connector).

Tap-applied method and drop-applied method are available for the cable connection. And DC 24V power is recommended to be installed on the position necessary to keep the voltage when lots of Dnet I/F modules are expected or the cable is expected to get long.



3) How to install the tap (8-port tap)


Connect to device port tap's trunk line where up to 8 connections and disconnections are available.




- (1) The drop line composed of Thick or Thin cable can be connected with the device through the tap. And if it is a Open-Style tap, 3 types of connectors can be used.
 - Pluggable screw type
 - Hard-wired screw type
 - Soldered type
- (2) The cable is most desirable to connect with drop line when the system does not operate. If the cable is to be connected when the system operates, check the connection status with other devices and let it connected with the trunk line so to avoid the influence on communication.
- (3) When connected with the trunk line, don't let the max. allowable length exceeded.

4) How to connect with network

(1) Max. network distance: stands for the distance between nodes most far away or between terminating resistors.



(2) Branch line length: stands for the length (max. 6m) from the first branched position of the trunk line to the last of the branch line.




(3) Communication distance compared with communication speed

Communication	Max. network length		Branch line	Branch line
speed	Thick	Thin	length	length in total
500kbps	100m or less			39m or less
250kbpS	250m or less	100m or less	6m or less	78m or less
125kbps	500m or less			156m or less

5) Branch line length in total


- Distance of accumulated branch line length (length of each branch line shall be within the max. 6m)



As for the configuration example above, since the branch line length is within 6m, there is no problem in the branch line length. However since the total length of the branch line is 40m which does not comply with the max. branch line length of 39m with communication speed of 500kbps, 250 and 125kpbs are only available for communication.

6) Network configuration and Checklist

Prior to the first network configuration, please check the system to be installed in the sequence as specified below;




7) Power arrangement


4 types of power arrangement are available as shown below.

At this time, the distance between power and power tap shall be within 3m.


(1) If node is arranged in both directions of power




(2) If node is arranged in a direction of power



(3) If the system of power supply is separated, with the plural power installed



(4) If power duplicated



3.2 From Setting to Operation

The sequence of the product from installation to operation will be described below. After the product installation is complete, install and configure the system to be operated as specified in the following sequence.

Operation Sequence

Install module on the base.

→ Check the applicable base/slot position for exact installation on the basic base.

Configure the system with module.

- → Use DeviceNet cable specified, terminating resistor, tap, communication power to configure the system.
- → Set the station number of slave module.

With power (master and slave module) On, check the LED status of the communication module.

→ Check if the interface of the communication module is normal (I/F: Flickering, Run: On, NMS: Green On) with CPU.

Execute SyCon

After Master is selected, Station number and Communication speed is specified then Auto Scan function scan the configured information of network.

 \rightarrow Check up the communication way of slave module whether the setting is correct and the module which is different from system configuration is corrected then Auto Scan function is operated.

Using XG-PD

1) Execute [Read IO information] \rightarrow 2) "High-speed link" \rightarrow 3) [Online]- [SyCon Upload] \rightarrow 4) Set the address of Read area/Save area for uploaded slave module \rightarrow 5) [Online] – [Write Parameter] \rightarrow 6) [Online] – [Enable Link].

XG-PD

1) [Online]-[Connection] \rightarrow 2) [Online] – [System Diagnosis] \rightarrow 3) Select the Master module in System diagnosis window and Check the system's operation status at "Highspeed link" and "Auto scan" (It appeared by right button click of selected area).


Start Run

Remark

1) When the first station No. is initialized, the value read from the communication module will be kept continuously. Thus, the details changed (station No., etc.) during communication will not be applied during operation.

3.3 Setting Procedure of SyCon and XG-PD


After setting the network configuration in SyCon software, then set the high speed link parameter and data in XG-PD software.



Chapter 4 System Configuration


4.1 System with LS Dnet I/F module used

Communication system between LS Dnet I/F modules can be configured as shown below. In the system, XGL-DMEA communication module shall be set to the master and the rest set to slave modules. In order to connect with LS inverter, Dnet I/F option module shall be installed on the applicable product to make the communication available.




4.2 System with LS Dnet I/F module and LS or other company's slaves mixed

In order to use other company's slave module, EDS (Electronic Data Sheet) file provided by its maker is necessary. Copy EDS file on the EDS folder of SyCon, the software tool for Dnet configuration and then use SyCon automatically to set the slave modules existent in the network.



4.3 System with Multi-master used


Communication system between LS Dnet I/F modules can be configured as shown below. In the system, set all the two XGL-DMEA modules to the master and then let the slave modules existent in the network shared with respective masters to make the communication available in the same network.



Chapter 5 SyCon Settings

5.1 SyCon S/W Environment

5.1.1 SyCon S/W configuration file




5.1.2 System requirement


- Pentium 486 MHz above
- Windows 95/98/ME/NT/2000/XP
 - Windows 95: Service Pack 1 above
 - Windows NT: Service Pack 3 above
- 80Mbytes minimum free space
- CD ROM Drive required
- RAM memory minimum 16Mbytes required
- Graphic Resolution: 800 x 600 pixel minimum
- Windows 95: Service Pack 1 above
- Windows NT: Service Pack 3 above

5.2 SyCon Program Installations

1) Executes 'Autorun.exe'.




- → Selects 'System Installation'.
- 2) Executes 'System Installation'.
 - (1) Do you want to install the System Configurator SyCon? → yes
 - (2) Do you want to install the SyCon Integrated OPC Server? → no
 - (3) Do you want to the Stand-Alone OPC Server/Busserver? → no
 - (4) Do you have a License code? → yes
 - (5) Select Language.




→ Select 'Next'.

3) License Agreement



→Select 'I agree'.

4) Program Registration



License Code: F90BF4B3E874

→ Select 'OK'.




→ Select 'Yes'.

5) Configuration setup




→ Select 'Next'.

(1) Components



→ Select 'Next'.

(2) Program Folder




→ Select 'Next'.



(3) Setup complete




- 6) Content installed
 - (1) Execution file




(2) Folder

- File destination: C:\Program Files\LS Industrial Systems\SyCon



(3) EDS file for DeviceNet

EDS file is created automatically as shown below.



5.3 SyCon Execution

Set the basic parameter for Dnet communication between master and slave. Master and slave configuration has 2 methods as shown below.

(1) Configuration with EDS file

Advantages: It can be set the slave which is not connected actually.

Disadvantages: If setting is wrong, the communication is operated abnormally.


(2) Auto Scan

Advantages: It can be set the parameter easily and speedy.


Disadvantages: It can be set only connected slave.

So, Use the methods properly by situation.

1) Initial screen execution



[Network]



[Editing screen]

2) Configuration menu

Main menu	Subr	menu			Description	Remark		
		New		Ма	ake New File.	M/S		
		Open			Open existed File.			
	<u>N</u> ew Ctrl+N	Close			ose activated file.	M/S		
	Open Ctrl+0 Close	Save	Save		ave activated file.	M/S		
	Save Ctrl+S Save As	Save A	S	Sa	ave activated file as another name.	M/S		
	Export	Export		Ex	port Project file.	M/S		
File	Copy EDS	Cany		ВМ Со	ppy DBM extension file.	M/S		
	Print, Ctrl+P Print Pre <u>v</u> iew	Сору	CSA C	SV Co	ppy CSV extension file.	M/S		
	Print Setup	Print		Pri	int.	M/S		
	Recent File	Print Pr	review	Pre	eview print.	M/S		
	E <u>x</u> it	Print Se	Print Setup		int setup.	M/S		
		Recent File		Dis	Display file list recently used.			
		Exit	Exit		Exit SyCon.			
	Cu <u>t</u> Ctrl+X	Cut	Cut		ıt.	S		
	<u>C</u> opy Ctrl+C	Сору	Сору		рру.	S		
Editor	Paste Ctrl+V Delete Ctrl+L	Paste			aste.	S		
	Replace Ctrl+R	Delete			elete.	S		
		Replace		Re	eplace.	M/S		
		Device	Device Table		Display of Network setting status.			
		Bovioc	Table	(M	IAC ID, Master/Slave)	M/S		
	<u>D</u> evice Table <u>A</u> ddress Table	Addres	Address Table		Display Input/Output size and slave module address.			
View	✓ Logical Network <u>V</u> iew	Logical	Network	Ch	nange into initial Logical Network View from			
	Toolbars ✓ Status Bar	View			liting screen.	M/S		
				rd To	activate standard menu bar.	M/S		
		Toolbars	Fieldb	ıs To	activate Insert Icon menu bar.	M/S		
		Status	·		o display Status Bar in basic SyCon screen.	M/S		
lma	Master	Master			selects to insert master module.	M/S		
Insert	<u>D</u> evice	Device	Device		selects to insert slave module.	M/S		

^{*} Remark

M: It means Master. It activates when master is selected in editing screen.

S: It means Slave. It activates when slave is selected in editing screen.

Main menu	Subme	nu	Description	Remark
		Download	To download SyCon setting file.	М
		Start Debug Mode	It displays present connection status.	М
		Device Diagnostic	It displays saved diagnostic information.	М
		Firmware Download	It is used for downloading Firmware.	М
	<u>D</u> ownload Ctrl+D	Firmware/Reset	Reset Firmware.	М
	Start Debug Mode	Extended Device Diagnostic	Extended diagnostic function of Device.	М
	Device Diagn <u>o</u> stic,,, Firm <u>w</u> are Download,,,	Global State Field	It displays present communication status and module status.	М
	Firmware / Reset Extended Device Diagnostic Ctrl+T			
	Global State Field Live List	Live List	It displays module's information and status per station number.	М
Online	J/O Monitor,	I/O Monitor	To display I/O data.	М
	Message Monitor	Message Monitor	Data analysis between Master and Slave	М
	Automatic Network Scan,	Automatic Network Scan	Set Network automatically.	М
	Get Device Attribute / Set Device Attribute,,, Start Communication Stop Communication	Get Device Attribute/ Set Device Attribute	Change of slave attribute.	S
	Devi <u>c</u> e Info	Start Communication	Start communication.	М
	Activate Dri <u>v</u> er	Stop Communication	Stop communication.	М
	Read Project Information,,	Device Info	Display of Device's manufacture data and Serial number.	М
		Activate Driver	Register unregistered device.	М
		Read project Information	Display Project information.	М
	Bus Parameters Master Settings Device Settings	Device Assignment	Set the method to communicate with Host.	М
	Device Configuration ✓ Auto Addressing Project Information	Bus Parameters	It is used for setting of communication speed and parameter.	М
	Pat <u>h</u>	Master Settings	Master module setting.	М
Settings	<u>L</u> anguage	Device Settings	-	-
		Device Configuration	Set Slave parameter.	S
		Auto Addressing	Assign the address automatically.	M/S
		Project Information	Project information.	M/S
		Path	GSD setting file and project path.	M/S
	<u> </u>	Language	Select language.	M/S
Window	1 Network View ✓ 2 Unnamed2	Cascade	Window array is Cascade mode.	M/S
VVIIIGOVV	Ualo Tanica	Tile	Window array is Tile mode.	M/S
Help	Help Topics About	Help Topics	View Help Topics.	M/S
i ioip		About	SyCon program information.	M/S


^{*} Remark

M: It means Master. It activates when Master is selected in editing screen.

S: It means Slave. It activates when Slave is selected in editing screen.

3) New File

Master must be set by New file, It can be set the slave automatically in Auto-scan.




4) Master/Slave selection


(1) Master

A) Selection

Method	Selection sequence
Menu bar	Insert → Master
Icon	■F los

B) Insertion






(2) Slave


It can be executed after master is inserted.

A) Selection

Method	Selection Sequence	Execution Icon
Menu bar	Insert → Slave	Ť
Icon	** <mark>}</mark>	D


B) Insertion








5) Master setting
To set Master, Master must be selected in editing screen.


(1) Setting sequence




















If the above 8 phases is finished, High-speed link setting is available after [SyCon Upload] at XG-PD. ($\boxed{\text{Online}} \rightarrow \boxed{\text{SyCon Upload}}$)

6) Slave module setting (Manual setting)
Slave module setting is available on the editor. Select slave module to edit.

(1) Setting sequence










7) Diagnosis

- ▶ To diagnose
 - It is possible to diagnose that the downloaded file exists at the same editing window.
 - It is possible to diagnose when master is selected in editing window.
 - To diagnose, above 2 conditions have to satisfy.
- ▶ It can confirm the station number, module type, communication speed, communication method and wire diagram through diagnosis.








5.4 Monitoring Information in SyCon

It monitors variable status information of communicating network.


1) Global State Field



Global State Field's description is as shown below.

lobal State Field's descrip	otion is as si	nown below.							
Classification			Description						
Online master main	OPERATE	Master module	e is operating.						
state	STOP			dule is not operation.					
	PDUP								
	DMAC								
	NRDY		cation of main progra	am is not ready.					
Collective status bits	EVE	Transmission							
Concouve states bits	FAT			because of fatal error.					
	NEXC			h Data Exchange State.					
	ACLR	All devices stop the communication and are cleared automatically.							
	CTRL	Master parame	eter error						
Collective online error location and	Error at rer	mote address		Error address displayed					
corresponding error	correspond	ding error event	Error event displayed						
		detected bus o	•	Counting the number of Bus off					
Statistic bus information	Counter of	rejected telegra	am transmissions Counting the rejected telegram transmissions						
	Paramete	rized Devices	Display of parameterized slave module (Blue)						
Device specific status	Activate	ed Devices	Display of activating slave module (Yellowish green) -The yellowish green is disappeared when slave module has the error.						
bits	Devices w	rith Diagnostic	Display of activating slave module (Red) -The diagnosis window is appeared when red color station is double-clicked. → Refer to 7) Diagnosis's 4 step.						

2) Live List



Chapter 6 High-speed Link Setting

6.1 Introduction

High-speed link specifies the Send/Receive device area and data size between CPU module and the communication module by XG-PD.

High-speed link can be set the function as shown below.

<u> </u>		set the function as shown below.						
Description			_	High-speed Link				
		Module type	Dnet					
	Communication module setting	Base no.	Setting range is different from CPU module.					
	module setting	Slot no.	t no. Max.: 0 ~ 11 Setting range is different from Base type.					
	Communication period setting (Period type)		nong 10ms, 20ms, 50ms, 100ms, 200ms, 500ms, 1s, 5s, 10s. setting: 10 ms					
		ODI I	Latch	Keep the previous output status.				
Communication	Output data setup	CPU error	Clear	Clear the output.				
	in case of emergency	ODLL -t	Latch	Keep the previous output status.				
	omorgonoy	CPU stop	Clear	Clear the output.				
module setting	Mode *1	Send : the data transfer from master module to slave module Receive : the data transfer from slave module to master module						
	Station No. *1	Slave static	Slave station number (Range: 0 ~ 63)					
	Communication Method *1	The communication method between master and slave(Poll, Bit-Strobe, COS, Cycli						
	Read area	Address	ddress Head address of the sending device Usable device: P, M, K, F, T, C, U, Z, L, N, D, R, ZR					
	(From Master to Slave module)	Size*1	lize*1 Input/Output point of slave module is displayed Byte.					
		(Byte)		/Output module is less than 8 bit, it is processed 1 Byte.				
	Save area	Address	Head address of the receiving device Usable device: P, M, K, F, T, C, U, Z, L, N, D, R, ZR					
	(From Slave to Master module)	Size ^{*1}	Input/Ou	tput point of slave module is displayed in Byte.				
	Master Module)	(Byte)		Output module is less than 8 bit, it is dealt with 1 Byte.				
	connection			ort of CPU module				
	rol condition			lless of position of Run mode switch (Run, Stop) of CPU module.				
Max. com	munication point	Transmission 28672 points, Reception 28672 points, Respectively 3584 Bytes						
	olock number	63 (Setting		,				
	oint per block	256 Byte ((2,048 poi	nt) (Setting range 1 ~ 256)				
	High-speed link setting	Up to 12						

Note

- *1:1) It can not set in XG-PD.
 - 2) It displays the uploaded data from SyCon to XG-PD.
 - 3) The setting sequence is from 1 phase to 2 phase.
 - 1 phase: Parameter setting in SyCon→Download
 - 2 phase: XG-PD → Read I/O information → SyCon upload → High-speed link parameter setting → Download the parameter → High-speed link permission


Setting value can be changed according to the changing phases (2 phase \rightarrow 1 phase).

- ▶ When High-speed link is edited, parameter has to download again.
- ▶ High-speed link is used per a communication module.
- ► CPU module saves the written parameter (Standard, High-speed link, P2P).

When CPU module is exchanged, parameter in XG-PD has to back-up and then the parameter has to write in CPU module again.

6.2 How to use XG-PD

XG-PD usage for Dnet I/F module is as shown below.




* Relation of Menubar and shortcut

	Menubar	Menu	Icon	Descriptions
	File	New file		Create a new file.
	New File Ctrl+N	Open	=	Open an exiting file.
	Open Ctrl+O Save Ctrl+S	Save		Save the file.
File	Save As Print Ctrl+P	Save As	-	Name and save the file.
	Print Preview Print Setup	Print	a	Print data.
	1 Untitled.xfg	Preview	-	Preview the data.
	Exit	Print Setup	-	Change the printer settings.
		Undo	-	Not used.
	Edit Undo Ctrl+Z	Cut	*	Delete an existing content and pastes that another part.
F 11.	Cut Ctrl+X Copy Ctrl+C	Сору		Copy the data in a file.
Edit	Paste Ctrl+V Delete	Paste		Paste the data in a file.
	Add Card	Delete	×	Delete the data in a file.
		Add Card	-	Not used.
		Connect		Connects PLC with a computer.
		Connection settings	3	Connection settings between PLC and the computer.
	Online ✓ Connect	Read IO information	3	Read the information of PLC.
	Connection Settings Read IO Information	Write Parameter	*	Write parameter to PLC from XG-PD.
	Write Parameter (Standard Settings, HS Link, P2P)	Read Parameter	=	Read parameter from PLC to XG-PD.
Online	Read Parameter (Standard Settings, HS Link, P2P) Enable Link (HS Link, P2P) Upload/Download(File)	Enable Link	-	Enabling the module to communicate via High-speed link or P2P communication.
	Sycon Upload (Dnet, Pnet)	Upload/Download (File)	-	Not used.
	System Diagnosis Reset	SyCon Upload		Read the data in SyCon.
	Reset	System Diagnosis		Monitoring of communication module's Run status.
		Reset	4	Reset the PLC.
Option	Option PLC Type Settings	PLC Type Settings	-	Set the type of CPU module.
	View	Toolbar	-	Activate the Toolbar.
View	✓ Toolbar ✓ Status Bar	Status Bar	-	Display the Status Bar.
View	Ascii Table ✓ Workspace Window	Ascii Table	-	Display the ASCII and Hexadecimal value.
		Workspace Window	-	Open/Close the parameter window.
	Window Cascade	Tile Horizontally	-	Tile the windows horizontally.
Window	Tile Horizontally Arrange Icon	Cascade	-	Cascade windows.
	✓ 1 High-speed Link Block settings - High-speed Link 9	Arrange Icon	-	Not used.
	Help VC DD Information	XG-PD information	8	Check the XG-PD version information.
Help	XG-PD Information MAC ADDR Download	MAC ADDR Download	-	Not used.


6.3 High-speed Link Editing

XG-PD is executed as shown below.



[Standard window]

The parameter in XG-PD is as shown below.




[Parameter window]

Dnet I/F module is set in High-speed link window. It can use the High-speed link up to maximum 12. A High-speed link is available per a Dnet I/F module.

1) How to use High-speed link window

Parameter is specified at High-speed link window as shown below. There are 2 kinds of parameter setting, Communication module setting and High-speed link block setting.



Remark

High-speed link1 [B0S0 Dnet] is as shown below.

- 1) High-speed link1: It is a serial number of High-speed link.
- 2) B0: It means Base number. (Example: Expansion base 2 stage B2, Expansion base 5 stage B5)
- 3) S0: It means Slot number. (Example: Slot number 5 S5, Slot number 11 S11)

Communication module setting parameter
 Communication module parameter setting is as shown below.

Parameter	Setting item			Description	
	Communi-	Communi- cation		Dnet	
Communication Module Settings	cation module			Setting range: 0 ~ 7 It is different from CPU module.	
Module type: Dnet	setting	Slot No	0.	Setting range: 0 ~ 11 It is different from type of base.	
	Communication period			Select among the 10ms, 20ms, 50ms, 100ms, 200ms, 500ms, 1s, 5s, 10s. - Default: 10ms	
Period type: 10 msec Output data setup in case of emergency				It is only for transmission data.Received data is processed every end of program.	
CPU error ○ Latch ⊙ Clear CPU stop ○ Latch ⊙ Clear		CPU	Latch	Keep the output status. (But, P device's data is cleared.)	
OK Cancel	Output data setup	error	Clear	Clear all of the output.	
	3 7		Latch	Keep the output status. (But, P device's data is cleared.)	
		stop Clear		Clear all of the output.	

Remark

Cautions of communication period setting

Setting value of communication period is applicable to transmission data (CPU module's data →
 Dnet I/F module). If communication period is longer than the time of changing data at scan
 program, It might be different from the data which is transmitted to slave module.

Parameter of High-speed link block setting
 High-speed link block setting parameter is as shown below.

(1) SyCon Upload

SyCon configuration must be uploaded before High-speed link block setting.

Upload way: Online → SyCon Upload (Dnet, Pnet)

Classificatio		Online → SyCon Upload (Dnet, Pnet)									
				High	n-sp	eed link	blo	ock setti	ng		
n											
	Index	Mode	Station number	Communication method	<u>'</u>	Read area	Se	nding data (Byte)	Save area	Receiving data (Byte)	
	1										
	3										
	<u>4</u> 5										
D - (6										
Before	7										
Upload	10						-				
0 1 1 1	11										
	13										
	15										
	16 17	-					-				_
	High-	speed									
	Index	Mode	Sta nun		ation d	Read area	•	Sending dal (Byte)	ta Save are	Receiving da (Byte)	ta
	0	Send		1 Poll				4			
	1	Receive Send/Rec		2 Poll				2		4	
	3	Sena/Hec	eive .	3 Poll			\neg	2		2	
	4	1			$\overline{}$		_				
After	5			After	⊒ مامین	ad the da	ato.				
Upload	6										
Opioau	7					n in SyCo					
	8 9					in High-sp	oee	a			
	10	1		ال ا	nk ۱	window.		\mathcal{F}			
	11	j									
	lui-b	,,,,,,								<u> </u>	
	High-	speed									

The uploaded information is as shown below.

Item	Description
Index	Arrange starting from the lowest station number in SyCon.
Station No.	Station number of slave module in network.
Communication	Display communication setting among the communication methods (Poll, Bit-Strobe,
method	Cyclic, COS).
Read area	Head address of transmitting device from master module to slave module.
Transmission data	Size of slave module (Byte).
Save area	Head address of receiving device from slave module to master module.
Reception data	Size of slave module (Byte).

The uploaded information in SyCon is not able to edit in XG-PD. In case of monitoring, SyCon has to upload again.

(2) High-speed link block editing

Head address of Send/Receive address can be edited in High-speed block.

Select index to edit and please set Read area & Save area.

Classification			·		Descriptio	n			
	Index	Mode	Station number	Communication method	Read area	Sending data (Byte)	Save area	Receiving data (Byte)	^
	0	Send	1	Poll	D00100	4			=
	1	Receive	9 2	Poll			М0000	4	
	2	Send/Rec	eive 3	Poll	D00120	2	M0010	2	
Screen	3			\wedge					
After	4		(11)						
	5 6		-	complete set	_				
uploaded	7			Read area area, the co					
the data	8		charac		anged				
	9			from red to black.					
	10			Trom red to black:					
	11								
		speed	'			'	'		
	_	ification			D-				
		*4			De	escription			
	Station	type '	Select slav						
	Block t	ype *1			transmitted from				
High-	Station	No. *1			(range: 0 ~ 63		o to madtor m	1000101	
speed link	Block N	No. *1		n Dnet I/F m	`				
block	Read a	rea	Address		ss of transmit ce: P, M, K, F	•	L. N. D. R. Z	 R	
editing	`		Size ^{*1}		point of slave m				
window	Slave	module)			ule point is less	•	•	Byte.	
WITIGOW	Save a (Slave								
	Ì		Size ^{*1}		point of slave m				
	Master	module)	(Byte)	- If input mod	ule point is less	s than 8 bit, it is	s dealt with 1 E	Byte.	


The priority order of data is the slave module which has lowest station number.

Remark

Unit of address setting is Word. But slave module's unit size is Byte. Less than 8 point module is processed by 1 Word when address is specified.


(3) How to use High-speed link block editing tool

The editing tool and usage of High-speed link block is as shown below.



6.4 Read and Write of High-speed Link


The screen is used for read/write of High-speed link's parameter.



If High-speed link parameter is written to CPU module, CPU module saves the data. If CPU module is exchanged, High-speed link parameter has to backup from CPU module. The parameter has to re-write in exchanged CPU module.

6.5 Enable Link





Chapter 6 High-speed Link Setting

* Enable Link through flag
It describes "Enable Link" method through flag. The following XG5000 version, CPU OS version is needed.

Item	Version
XG5000	V3.61 or above
XGR CPU	V1.91 or above
XGI CPU	V3.4 or above
XGK CPU	V3.7 or above

Flag list related with "Enable Link" -XGR

Flag Data type		Device	Description
_HS_ENABLE_STATE	ARRAY[011] OF BOOL	%FX19040	HS link enable/disable current state
_HS_REQ	ARRAY[011] OF BOOL	%FX31520	HS link enable/disable request
_HS_REQ_NUM	ARRAY[011] OF BOOL	%FX31536	HS link enable/disable setting
_P2P_ENABLE_STATE	ARRAY[07] OF BOOL	%FX19072	P2P enable/disable current state
_P2P_REQ	ARRAY[07] OF BOOL	%FX31552	P2P enable/disable request
_P2P_REQ_NUM	ARRAY[07] OF BOOL	%FX31568	P2P enable/disable setting

-XGI

Flag	Data type	Device	Description
_HS_ENABLE_STATE	ARRAY[011] OF BOOL	%FX15840	HS link enable/disable current state
_HS_REQ	ARRAY[011] OF BOOL	%FX16480	HS link enable/disable request
_HS_REQ_NUM	ARRAY[011] OF BOOL	%FX16496	HS link enable/disable setting
_P2P_ENABLE_STATE	ARRAY[07] OF BOOL	%FX15872	P2P enable/disable current state
_P2P_REQ	ARRAY[07] OF BOOL	%FX16512	P2P enable/disable request
_P2P_REQ_NUM	ARRAY[07] OF BOOL	%FX16528	P2P enable/disable setting

-XGK

-XGK			
Flag	Data type	Device	Description
_HS1_ENABLE_STATE	BIT	F09600	HS link 1 enable/disable current state
_HS2_ENABLE_STATE	BIT	F09601	HS link 2 enable/disable current state
_HS3_ENABLE_STATE	BIT	F09602	HS link 3 enable/disable current state
_HS4_ENABLE_STATE	BIT	F09603	HS link 4 enable/disable current state
_HS5_ENABLE_STATE	BIT	F09604	HS link 5 enable/disable current state
_HS6_ENABLE_STATE	BIT	F09605	HS link 6 enable/disable current state
_HS7_ENABLE_STATE	BIT	F09606	HS link 7 enable/disable current state
_HS8_ENABLE_STATE	BIT	F09607	HS link 8 enable/disable current state
_HS9_ENABLE_STATE	BIT	F09608	HS link 9 enable/disable current state
_HS10_ENABLE_STATE	BIT	F09609	HS link 10 enable/disable current state
_HS11_ENABLE_STATE	BIT	F0960A	HS link 11 enable/disable current state
_HS12_ENABLE_STATE	BIT	F0960B	HS link 12 enable/disable current state
_HS1_REQ	BIT	F10300	HS link 1 enable/disable request
_HS2_REQ	BIT	F10301	HS link 2 enable/disable request
_HS3_REQ	BIT	F10302	HS link 3 enable/disable request
_HS4_REQ	BIT	F10303	HS link 4 enable/disable request
_HS5_REQ	BIT	F10304	HS link 5 enable/disable request
_HS6_REQ	BIT	F10305	HS link 6 enable/disable request
_HS7_REQ	BIT	F10306	HS link 7 enable/disable request
_HS8_REQ	BIT	F10307	HS link 8 enable/disable request
_HS9_REQ	BIT	F10308	HS link 9 enable/disable request
_HS10_REQ	BIT	F10309	HS link 10 enable/disable request
_HS11_REQ	BIT	F1030A	HS link 11 enable/disable request
_HS12_REQ	BIT	F1030B	HS link 12 enable/disable request
_HS1_REQ_NUM	BIT	F10310	HS link 1 enable/disable setting
_HS2_REQ_NUM	BIT	F10311	HS link 2 enable/disable setting

Chapter 6 High-speed Link Setting

Flag	Data type	Device	Description
_HS3_REQ_NUM	BIT	F10312	HS link 3 enable/disable setting
_HS4_REQ_NUM	BIT	F10313	HS link 4 enable/disable setting
_HS5_REQ_NUM	BIT	F10314	HS link 5 enable/disable setting
_HS6_REQ_NUM	BIT	F10315	HS link 6 enable/disable setting
_HS7_REQ_NUM	BIT	F10316	HS link 7 enable/disable setting
_HS8_REQ_NUM	BIT	F10317	HS link 8 enable/disable setting
_HS9_REQ_NUM	BIT	F10318	HS link 9 enable/disable setting
_HS10_REQ_NUM	BIT	F10319	HS link 10 enable/disable setting
_HS11_REQ_NUM	BIT	F1031A	HS link 11 enable/disable setting
_HS12_REQ_NUM	BIT	F1031B	HS link 12 enable/disable setting
_P2P1_ENABLE_STATE	BIT	F09620	P2P1 enable/disable current state
_P2P2_ENABLE_STATE	BIT	F09621	P2P2 enable/disable current state
_P2P3_ENABLE_STATE	BIT	F09622	P2P3 enable/disable current state
_P2P4_ENABLE_STATE	BIT	F09623	P2P4 enable/disable current state
_P2P5_ENABLE_STATE	BIT	F09624	P2P5 enable/disable current state
_P2P6_ENABLE_STATE	BIT	F09625	P2P6 enable/disable current state
_P2P7_ENABLE_STATE	BIT	F09626	P2P7 enable/disable current state
_P2P8_ENABLE_STATE	BIT	F09627	P2P8 enable/disable current state
_P2P1_REQ	BIT	F10320	P2P1 enable/disable request
_P2P2_REQ	BIT	F10321	P2P2 enable/disable request
_P2P3_REQ	BIT	F10322	P2P3 enable/disable request
_P2P4_REQ	BIT	F10323	P2P4 enable/disable request
_P2P5_REQ	BIT	F10324	P2P5 enable/disable request
_P2P6_REQ	BIT	F10325	P2P6 enable/disable request
_P2P7_REQ	BIT	F10326	P2P7 enable/disable request
_P2P8_REQ	BIT	F10327	P2P8 enable/disable request
_P2P1_REQ_NUM	BIT	F10330	P2P1 enable/disable setting
_P2P2_REQ_NUM	BIT	F10331	P2P2 enable/disable setting
_P2P3_REQ_NUM	BIT	F10332	P2P3 enable/disable setting
_P2P4_REQ_NUM	BIT	F10333	P2P4 enable/disable setting
_P2P5_REQ_NUM	BIT	F10334	P2P5 enable/disable setting
_P2P6_REQ_NUM	BIT	F10335	P2P6 enable/disable setting
_P2P7_REQ_NUM	BIT	F10336	P2P7 enable/disable setting
_P2P8_REQ_NUM	BIT	F10337	P2P8 enable/disable setting

[►] How to enable link

⁻HS link/P2P enable/disable setting flag ON \rightarrow HS link/P2P enable/disable request flag ON


[►] How to disable link

⁻HS link/P2P enable/disable setting flag OFF → HS link/P2P enable/disable request flag ON

[▶] You can monitor the Enable/Disable state of the each link through "enable/disable current states" flag.


6.6 System Diagnosis


System diagnosis provides the information of Dnet I/F module system. The System diagnosis screen is as shown below.



It describes the menu of system diagnosis.

Menu	Screen configuration and description			
	Communication Module Information [] [] [] [] [] [] [] [] [] [Module Kind Base	Communication module type. Base number of communication module which is
	Module kind XGL-0MEA Base number 0	Standard	number	connected with High-speed link.
Communic-	Hardware Erat	information	Slot number	Slot number of communication module which is
ation				connected with High-speed link.
module			Hardware	Hardware error of communication module.
information		Hardware/	Error	Thataware error or communication mediale.
		Software	Hardware	Hardware version of communication module.
	Close	information	version	
			OS Version	Software version of communication module.







6.7 High-speed Link Information

High-speed link swaps the data between master module and all slave modules. It provides the flag of High-speed link operation status classified by individual station or total station. It is useful when checking the reliability of Transmission/Reception data and finding cause of error. Flag kinds and usage is as shown below.

Classification	Run-Link	Link-Trouble	Transmission /Reception status	Operation mode	Error	High-speed link status
Information type	All		Respectively			
Flag name (x=High-speed link number)	_HSxRLINK	_HSxLTRBL	_HSxTRX[n] (n=063)	_HSxMOD[n] (n=063)	_HSxERR[n] (n=063)	_HSxSTATE[n] (n=063)
Data type	Bit	Bit	Bit Array	Bit Array	Bit Array	Bit Array
Monitoring	Available	Available	Availability	Availability	Availability	Availability
Program use	Available	Availability	Availability	Availability	Availability	Availability

[Table] Function of High-speed link information






Chapter 7 Communication Program

7.1 Example Program

Basic configuration of example and setting value is as shown below.


Basic configu	iration of	example and set	ting value is as	snown bei	OW.		
	С	lassification		Description		Setting	Setting
	1	1		•		program	phase
		Master setting		XGL-DMEA		SyCon	1-3 ~ 1-4
		Base number			0	XG-PD	5-1
	Master	Slot number			0	XG-PD	5-1
	IVIASIEI	Station number			0	SyCon	1-5, 3-1
	module	Communication sp	eed	12	25kbps	SyCon	3-1
		High-speed link se	etting	High-spe	ed link 1 area	XG-PD	5-1
		Communication pe	eriod setting	2	200ms	XG-PD	5-1
		Slave type		GDL-TR4A,GE	DL-D24A,GDL-DT4A	SyCon	4-1 ~ 4-4
			Station no.		1	SyCon	4-3, 5-2
	System (Output 3	GDL-TR4A	Communication method		Poll	SyCon	5-3
0		(Output 32 points)	Save area	Device	M100	XG-PD	6-1
System				Size	4		6-1
configuration		CDL D24A	Station no.	2		SyCon	4-3, 5-2
			Communication	COS (Change of State)		CuCon	5-3
		(Input 32 points)	method	(Transmission	on period: 200ms)	SyCon	(5-4)
		(Input 32 points)	Read area	Device	M110	XG-PD	6-1
				Size	4	AG-PD	0-1
			Station no.	3		SyCon	4-3, 5-2
			Communication	COS (Change of State)		SyCon	5-3
		GDL-DT4A	method	(Transmission period: 200ms)		Sycon	(5-4)
		(Output 16 points,	Read area	Device	M102	XG-PD	6-1
		Input 16 points)	Neau alea	Size	2	AG-FD	6-1
		Savo area	Device	M112	XG-PD	6-1	
			Save area	Size	2	Λ G- FD	0-1
	Master S	etting		Change of basic setting		SyCon	2-1 ~ 2-3
Etc.				value		<u> </u>	
	Device Assignment			Setting of computer's		SyCon	6-1 ~ 6-2
			communication port				

• Configuration of system




[SyCon 1 phase] Master and MAC ID setting

Menu: File → New



[SyCon 2 phase] Change of Basic setting

Menu: Settings → Master Settings




^{*}Only 'Handshake of the process data' setting can be set.

Chapter 7 Communication Program

[SyCon 3 Phase] Baudrate


Menu: Settings → Bus Parameter




- * Auto clear mode
 - (1) If Auto clear mode is selected
 - \rightarrow If error is occurred in slave module, the communication stops for the whole system.
 - → Dnet I/F module's HS LED is flickering, MNS LED red light flickering.
 - (2) If Auto clear mode is not selected
 - → If error is occurred in slave module, the communication keeps for normal slave module.

[SyCon 4 phase] Slave and MAC ID setting

Menu: Insert → Master





[SyCon 5-1 phase] Slave module communication methods setting – Slave module: GDL-TR4A

Menu: Settings → Device Configuration

Phase	Item	Screen configuration and setting description
Phase 5-1	Slave communication methods setting	Slave module setting Device Configuration MAC ID
5-2	Slave MAC ID	MAC ID setting: 1 MAC ID 1 File name GDL-TR4A,EDS Description Device1 ✓ Activate device in actual configuration
5-3	Slave communication method	Communication method: Poll -Actual chosen IO connection - Poll Bit strobe C Change of state C Cyclic UCMM check
5-4	Slave Transmission/ Reception period setting	Transmission/Reception data period and response condition setting → Poll is default communication method. Connection Object Instance Attributes Expected packet rate 200 Production inhibit time 10 Watchdog timeout action Timeout Fragmented Timeout 1600 ms Produced connection size 0 Consumed connection size 4
5-5	Slave data structure (EDS File)	Information of EDS File (Data type, Input/Output characteristic, Data length). Available predefined connection data types Data type Data type Description Data length Discrete Output Data Append to configured I/O data Insert into configured I/O data displayed as next 5-6 phase.
5-6	Slave data structure	Slave structure (Data type, Input/Output characteristic, Data length) is transmitted to master module. - Configured I/O connection data and its offset address - Data type Description Type Len. Addr.

[SyCon 5-2 phase] Slave communication method setting – slave module: GDL-D24A

Menu: Settings → Device Configuration

Phase	Item	Screen configuration and setting description
5-1	Slave communication method setting	Slave setting Device Configuration MAC ID 2 File name GDL-D24A,EDS Description Device2 Actual device in actual configuration Actual chosen IO connection Poll Bit strobe Change of state Cyclic UCMM check Group 3 Connection Object Instance Attributes Expected packet rate 200 Production inhibit time 10 Expected packet rate 200 Production inhibit time 10 Produced connection size 0 Consumed connection size 0 Available predefined connection data types Data type Description Data length BYTE ARRAY Discrete Input Data 4 Append to configured I/O data Insert into configured I/O data
		Data type Description Type Len. Addr. O Type O Len. O Addr. Delete configured I/O data Symbolic Names
5-2	Slave MAC ID	MAC ID: 2 MAC ID 2 File name GDL-D24A,EDS Description Device2 Activate device in actual configuration
5-3	Slave communication method	Communication method : COS (Change of State) - Actual chosen IO connection————————————————————————————————————
5-4	Slave Transmission /Reception period setting	Transmission/Reception data period and response condition setting → Expected packet rate must be 200ms in COS (Change of State) communication method. (Expected packet rate must be larger than production inhibit time.) Connection Object Instance Attributes Expected packet rate Watchdog timeout action Produced connection size Consumed connection size 4
5-5	Slave data structure (EDS File)	Information of EDS File (Data type, Input/Output characteristic, Data length). Available predefined connection data types Data length BYTE ARRAY Discrete Input Data Append to configured I/O data Insert into configured I/O data Append to configured I/O data Insert into configured I/O data Insert into configured I/O data displayed as next 5-6 phase.
5-6	Slave data structure	Slave structure (Data type, Input/Output characteristic, Data length) is transmitted to master module. Configured I/O connection data and its offset address Data type Description Type I Len. I Addr. 0 Type 0 Len. 0 Addr. BYTE ARRAY Discrete_Input_Data IB 4 0 Delete configured I/O data Symbolic Names

[SyCon 5-3 phase] slave communication method setting – slave module: GDL-DT4A


Menu: Settings → Device Configuration

Phase	Item	Screen configuration and setting description
Slave		Slave setting Device Configuration MAC ID 3 File name GDL-DT4A,EDS Description Device3 Actual device in actual configuration Actual chosen IO connection Connection Object Instance Attributes Expected packet rate Watchdog timeout action Timeout Fragmented Timeout Timeout
	communication method setting	Produced connection size 0 Consumed connection size 0 Available predefined connection data types Data type Description Data length BYTE ARRAY Discrete Input Data 2 BYTE ARRAY Discrete Output Data 2 Append to configured I/O data Configured I/O connection data and its offset address Data type Description I Type I Len. I Addr. 0 Type 0 Len. 0 Addr. Delete configured I/O data
		▼ Symbolic Names
5-2	Slave MAC ID	MAC ID: 3 MAC ID 3 File name GDL-DT4A,EDS Description Device3 Activate device in actual configuration
5-3	Slave communication method	Communication method: COS (Change of State) Actual chosen IO connection C Poll Bit strobe Change of State C Cyclic
5-4	Slave Transmission /Reception period setting	Transmission/Reception data period and response condition setting → Expected packet rate must be 200ms in COS (Change of State) communication method. (Expected packet rate must be larger than production inhibit time.) Connection Object Instance Attributes Expected packet rate Watchdog timeout action Produced connection size Consumed connection size 4
5-5	Slave data structure (EDS File)	Information of EDS File (Data type, Input/Output characteristic, Data length). Available predefined connection data types Data type BYTE ARRAY Discrete Input Data 2 BYTE ARRAY Discrete Output Data 2 Append to configured I/O data Insert into configured I/O data displayed as next 5-6 phase.
5-6	Slave data structure	Slave structure (Data type, Input/Output characteristic, Data length) is transmitted to master module. - Configured I/O connection data and its offset address - Data type Description Type Len. Addr. O Type O Len. O Addr. BYTE ARRAY Discrete_Input_Data B 2 4 BYTE ARRAY Discrete_Output_Data QB 2 4 Delete configured I/O data Symbolic Names

[SyCon 6 phase] Serial port selection

The cable diagram is same as RS-232C cable diagram using in CPU module. Use same kind cable.

Menu: Settings → Device Assignment




[SyCon 7 phase]

Menu: Online → Download

Chapter 7 Communication Program


[XG-PD 1 phase] Select CPU module type

Menu: Option - PLC Type Settings



[XG-PD 2 phase] Connection settings

Menu: Online - Connection settings



[XG-PD 3 phase] Connection


Menu: Online - Connection

[XG-PD 4 phase] Read IO information

Menu: Online - Read I/O information

[XG-PD 5 phase] High-speed link setting

Menu: Parameter → High-speed link (HS Link) → High-speed link1



[XG-PD 6] SyCon Upload (Dnet, Pnet)

Menu: Online → SyCon Upload (Dnet, Pnet)


[XG-PD 6 Phase] Read area/Save area setting

Menu: HS Link \rightarrow High-speed link1 \rightarrow block

Phase	Item	Screen configuration and setting description														
		Initia	al scree	en								•				
		Index	Mode	Station	Commur	nication	Read area	Seno	ding data	Save a	rea R	eceiving data				
		0	Send	numbe	r met		Trodd diod	1	Byte) 4	00100		(Byte)				
		1 2	Receive Send/Rece		C0				2			4 2				
		3	Sena/Hece	ive 3	CL	15			2							
		5														
		6											v			
			peed									1.5				
		Sele	Select index of block window													
			ave	Index	,				High.	.cnaar	llink	block se	ttine	,		
		mo	dule	muez	`				riigii	Speec	ı III IK	DIOCK 36	uniç	1		
						Index	Mode	Station number	Communic metho	ation R	lead area	Sending da (Byte)	ita	Save area	Receiving data (Byte)	
						0	Send	1	Poll		M0100	4				
						2	Receive Send/Receive	3	cos cos			2	_		2	
		GDL.	-TR4A	0		3 4										
						5								Save area Receiving data (Byte) M0110 4		
						6 7							_		<u>~</u>	
	Communication					High-speed										
						Index	Mode	Station number	Communic metho		lead area	Sending da (Byte)	ita	Save area	Receiving data (Byte)	
						0	Send	1 2	Poll COS		M0100	4		140110	<u> </u>	
6-1	module					2	Receive Send/Receive	3	COS			2	Ę	MUITU	2	
'		GDL-D24A		D24A 1		3										
	setting									5						
						7							_			<u> </u>
						High-	speed									
						Index	Mode	Station number	Communic metho	d n	Read area	Sending da (Byte)	ita	Save area	Receiving data (Byte)	
		ODI DTAA				1	Send Receive	2	Poll COS		M0100	4		M0110	4	-
				_		2	Send/Receive	3	cos		M0102	2	_	M0112	2	
		GDL.	-DT4A	2		4										
						5 6										
						High-	i speed									
		⊔iah	cnoo	d link l	alock	$\overline{}$		oroc	/Sov/	oroc	n cott	ting				
			Т		Station		er Read				ng data			Receivin	n data	l
		Inde		ode	number	1	method	Read		(B)	yte)	Save	Save area Recei		e) <u> </u>	
		0	_	end ceive	2		Poll COS	M0	100		4	M01	10	4		
		2		Receive	3		cos	M0	102		2	M01		2		
		3										1				
		5														
		6														
		7	1												<u>~</u>]
		High	-speed													

[XG-PD 7 phase] Write High-speed link parameter

Menu: Online → Write Parameter



- Written parameter is saved CPU module.
 - If CPU module is exchanged, High-speed link parameter has to backup from used CPU module.

[XG-PD 8 phase] High-speed link enabling

Menu: Online → Enable Link (HS Link, P2P)


→ Communication is permitted between master module and slave module.

7.2 Example Program (XDL-BSSA setting)

Basic configuration and setting value for example is as below.

		Setting item			Setting	Software	Phase
		Master setting		XG	L-DMEA	SyCon	1-3 ~ 1-4
		Base no.			0	XG-PD	5-1
		Slot no.			0	XG-PD	5-1
_	Master	Station no.			0	SyCon	1-5, 3-1
configuration		Communication speed		12	25kbps	SyCon	3-1
<u>ra</u>		High Speed Link setting		High S	peed Link 1	XG-PD	5-1
l ig		Communication cycle setting		2	00ms	XG-PD	5-1
ınf		Select slave		XDL-BSSA		SyCon	4-1 ~ 4-4
		XDL-BSSA (XBE-TN32A:Tr. Output	Station no.	3		SyCon	4-3, 5-2
System			Communication method	Poll		SyCon	5-3 (5-4)
S	Slave	XBE-RY16A:Relay Output XBE-DC32A:DC Input	Read area	Device	P1000	VC DD	6.1
		XBF-AD04A:A/D Conversion module		Size	14	XG-PD	6-1
		XBE-DV04A:D/A Conversion module)	Cava area	Device	M200	XG-PD	6.1
		ADE-DVO+A.BIA CONVEISION Module)	Save area	Size	12	AG-PD	6-1
	Master Setting				asic setting value	SyCon	2-1 ~ 2-3
Etc.	Etc. Device Assignment				Communication port setting of computer		6-1 ~ 6-2

• System Configuration



I/Ò

points

32points

(4Byte)

16Points

(2Byte)

32Points

(4byte)

64Points


(8Byte)

64Points

(8Byte)


[SyCon 1 Phase] Master and station no. setting

Menu selection : File → New



[SyCon 2 Phase] Basic setting change


Menu selection : Settings → Master Settings



* Please don't set exclusive of "Handshake of the process data".

[SyCon 3 Phase] Communication speed

Menu selection : Settings → Bus Parameter





* Auto Clear Mode

- (1) When it is selected
- → If it is occurred to error in slave module, communication stop on overall system.
- → HS LED flickering of Dnet I/F module MNS Red LED On
- (2) When it is not selected
- → If it is occurred to error in slave module, communication is kept about normal slave Module.

[SyCon 4 Phase] Slave and station no. setting

Menu selection : Insert → Device





[SyCon 5 Phase] Slave communication method setting - Slave : XDL-BSSA

Menu selection : $\overline{\text{Settings}} \rightarrow \overline{\text{Device Configuration}}$


Phase	Item	Screen configuration and setting description					
5-1	Setting window for slave communication method	Slave setting Device Configuration MAC ID 3 File name XDL-BSSA,EDS Description Device1 For Activate device in actival configuration Actual chosen IO connection Poll Bit strobe Change of state Cyclic UCMM check Group 3 Connection Object Instance Attributes Expected packet rate 200 Production inhibit time II0 Produced connection size 0 Available predefined connection data types Data type Description Data length Bit Input, Bit 1 Bit Input, Bit 1 Bit Output, Bit 1 Bit Input, Byte 1 Bit Input, Byte 1 Bit Input, Byte 1 Configured I/O connection data and its offset address Data type Description IType I Len. IAddr. In Type I Len. IAddr. In Type II Len. II Addr. In Type II Len.					
5-2	Slave station no	Station no. (MAC ID) setting: 3 MAC ID [3 File name XDL-BSSA,EDS Description [Device1] Activate device in actual configuration					
5-3	Slave communication method	Communication method selection : Poll Actual chosen IO connection Poll Distribute Change of state Chyclic LUCMM check					
5-4	Slave Send/Receive cycle	Send/Receive cycle of slave module and condition setting of response status →Poll method is set by default value Connection Object Instance Attributes Expected packet rate 200 Production inhibit time 10 Watchdog timeout action Timeout Fragmented Timeout 1600 ms Produced connection size 0 Consumed connection size 4					
5-5	Slave Data Configuration (EDS File)	EDS File information(Data type, Input/Output Description, Data size) Available predefined connection data types Data type Description Data length BIT					
5-6	Slave Data Configuration	Slave configuration(Data type, Input/Output Description, Data size)is transferred to master. Configured I/O connection data and its offset address Data type Description I Type Len. I Addr. O Type O Len. O Addr. BYTE ARRAY Module2 QB 14 O QB 14 O Qelete configured I/O data Symbolic Names					

[SyCon 6 Phase] Serial port selection

: It is the same with the wiring of RS-232C Loader Cable to be used through CPU module.

Therefore you have to use that cable.

Menu selection : Settings → Device Assignment




[SyCon 7 Phase] Download

Menu selection : OnLine → Download


[XG-PD 1 Phase] CPU module type selection

Menu selection : Option – PLC type setting



[XG-PD 2 Phase] Communication method setting

Menu selection : Online - Connection setting



[XG-PD 3 Phase] Connection


Menu selection: Online - Connection

[XG-PD 4 Phase] I/O information reading

Menu selection : Online - I/O information setting

[XG-PD 5 Phase] High Speed Link setting

Menu selection : Parameter → High Speed Link(HS Link) → High Speed Link 1




[XG-PD 6 Phase] SyCon Upload

Menu selection : Online → SyCon Upload (Dnet)

Phase	Item		Screen configuration and setting description							
		Initial	screen					•		
		Index	Mode	Station number	Communication method	Read area	Sending a data (Byte)	_ Save ar	Receiving ea data (Byte)	
		0								
		1 2	<u> </u>							-
		3								-
		4								
		5								<u>~</u>
		High-	speed							
		Index	selection	of blo	ck screen					
	Communication	Index	Mode	Station number	Communication method	Read area	Sending a data (Byte)	Save ar	Receiving rea data (Byte)	
6-1	module	1	_							-
	setting	2								-
	Setting	3								-
		4								
		5								~
		High∹	speed							
		00-								
		Syco	n Upload		1 1	ı	Sending	-	Receiving	_
		Index	Mode	Station number	Communication method	Read area	data (Byte)	Save area	data (Byte)	
		0	Send/Receive	3	Poll		14		12	
		1 2								
								-		~
		High-s	peed							

[XG-PD 6 Phase] Read area/Save area setting

Menu selection : Parameter → High Speed Link(HS Link) → High Speed Link 1 → Block



- Read area/Save area configuration of slave module
 - 1. I/O configuration of Dnet module of extendable type


Communication Adapter					
Read area Slot0: Slot1: Slot3:	Slot 0: P1000 Tr. Output	Slot 1: P1002 Relay Output	Slot 2: M0200 DC Input	Slot 3: P1003 DA Output	Slot 4: M0202 AD Input
Save area Slot2: Slot4:	32points (XBE- TN32A)	16points (XBE- RY16A)	32points (XBE- DC32A)	(XBF- DA04A)	(XBF- AD04A)

2. Read area/Save area of module

Read are:	r→Slave)	Save area(Slave→Master)						
Device	Tx Data		Extendable Output Module		Device	Rx Data		Extendable Input Module	
P1000	14	4Byte	TR Output 32points		M0200	12	4Byte	DC Input 32	points!
P1002	Byte	2Byte	Relay 16poir	nts	M0202	Byte	2Byte	A/D	Ch0
P1003		2Byte	D/A	Ch0	M0203		2Byte	Conversion	Ch1
P1004		2Byte	Conversion	Ch1	M0204		2Byte	4Ch	Ch2
P1005		2Byte	4Ch	Ch2	M0205		2Byte		Ch3
P1006		2Byte		Ch3					, and the second

[XG-PD 7 Phase] High Speed Parameter Writing

Menu selection : Online → Parameter writing



- The parameter wrote is saved to CPU module.
 - Therefore if you exchange CPU module, you have to backup the parameter of High Speed Link.

[XG-PD 8 Phase] High Speed Link enable

Menu selection : Online → Link enable(High speed link, P2P)

→ Enable the communication between master module and slave module

Chapter 8 Troubleshooting

This chapter is to describe various errors that may occur in system operation, their causes and actions to take against. If any error occurs on the communications module, related error details will be displayed through LED of the communication module. Follow the procedures below to shoot the troubles after checking for errors displayed, based on the applicable LED status referring to product specification.

8.1 Symptoms and Management by LED Status

It shows the symptoms of communication module by LED status and the management. (When High-speed link is enabled)

RUN	I/F	HS	D-RUN	MNS	Symptoms	Management	
ON	Flickering	OFF	Flickering	Green ON	High-speed link disable	-	
ON	Flickering	ON	ON	Red ON	Slave connection abnormal	Slave connection check Check slave setting	
ON	Flickering	Flickering	Flickering	Green ON	SyCon setting changed while High-speed link is executed	-	
ON	Flickering	Flickering	Flickering	Red ON	Whole slave connection error	Check slave connection Check slave setting	
OFF	OFF	OFF	-	-	Critical defect	Ask customer service center	

[Table 8.1] The symptoms of communication module error (High-speed link is enabled)

8.2 System Diagnosis in XG-PD

It shows the diagnosis item in XG-PD.

Diagnosis item	Description
Communication	
module	It displays the standard information of communication module.
information	
High-speed link	It displays the flag information of High-speed link.
Log	It displays system log and running log.
Auto-scan	It displays the slave module which is connected Dnet I/F module.

[Table 8.2] System diagnosis in XG-PD

It diagnoses the system by [Online] - [System Diagnosis] in XG-PD.


8.2.1 Communication module information

It displays the information of Dnet I/F module.



[Figure 8.1] Communication module information

8.2.2 High-speed link




[Figure 8.2] High-speed link

	High-spe	ed link diagnosis
Classification (Main item)	Classification (Sub item)	Description
Standard information	Base no. Slot no. Master st.	Base number: 0~7 Slot number: 0~11 Master station number
Total High-speed link information	Run link	Normal: All station is a normal communication. Error: If only one station can not to communicate, it is an error.
	Link trouble	Communication line's status
	Index	High-speed link parameter index (High-speed link block number in XG-PD)
	Station number	Master station number
	Communication method	Slave's communication method
Individual High-	Size of transmitted data	Transmission data size (Byte)
speed link	Size of recepted data	Received data size (Byte)
information	Mode	Present operation status
	Transmission/Reception status	transmission/reception status
	High-speed link status	High-speed link status
	Error	Error status

[Table 8.3] High-speed link diagnosis

8.2.3 Autoscan


It displays the slave module which is connected Dnet I/F module.



[Figure 8.4 Autoscan]

8.3 Diagnosis of Communication Module through XG5000

It can monitor the communication status by XG-5000. Connect to CPU port and [Online] – [PLC History] – [PLC Errors/Warnings].




[Figure 8.5] Detailed information of PLC history

If hardware error or CPU interface error is occurred, communication module's LED operates abnormally. Also, the error information is shown through XG-5000.


[Figure 8.5] shows Error/Warning information from [Online] - [PLC History] menu in XG-5000.

8.4 Trouble shooting for Respective Error


8.4.1 SyCon communication error



8.4.2 XG-PD abnormal connection



8.4.3 Communication error with slave module



A.1 List of Flags

A.1.1 Special relays

Device 1	Device 2	Туре	Variable	Function	Description
F0000		DWORD	_SYS_STATE	Mode & Status	PLC mode & run status displayed.
	F00000	BIT	_RUN	RUN	RUN status.
	F00001	BIT	_STOP	STOP	STOP status.
	F00002	BIT	_ERROR	ERROR	ERROR status.
	F00003	BIT	_DEBUG	DEBUG	DEBUG status.
	F00004	BIT	_LOCAL_CON	Local control	Local control mode.
	F00005	BIT	_MODBUS_CO	Modbus mode	Modbus control mode.
	F00006	BIT	_REMOTE_CO N	Remote mode	Remote control mode.
	F00008	BIT	_RUN_EDIT_ST	Modification during run	Program being downloaded during run.
	F00009	BIT	_RUN_EDIT_C HK	Modification during run	Modification in progress during run.
	F0000A	BIT	_RUN_EDIT_D ONE	Modification complete during run	Modification complete during run.
	F0000B	BIT	_RUN_EDIT_E ND	Modification complete during run	Modification complete during run.
	F0000C	BIT	_CMOD_KEY	Run Mode	Run Mode changed by key.
	F0000D	BIT	_CMOD_LPADT	Run Mode	Run Mode changed by local PADT.
	F0000E	BIT	_CMOD_RPAD T	Run Mode	Run Mode changed by remote PADT.
	F0000F	BIT	_CMOD_RLINK	Run Mode	Run Mode changed by remote communication module.
	F00010	BIT	_FORCE_IN	Compulsory input	Compulsory input status.
	F00011	BIT	_FORCE_OUT	Compulsory output	Compulsory output status.
	F00012	BIT	_SKIP_ON	I/O SKIP	I/O SKIP being executed.
	F00013	BIT	_EMASK_ON	Error mask	Error mask being executed.
	F00014	BIT	_MON_ON	Monitor	Monitor being executed.
	F00015	BIT	_USTOP_ON	STOP	Stopped by STOP function
	F00016	BIT	_ESTOP_ON	ESTOP	Stopped by ESTOP function.
	F00017	BIT	_CONPILE_MO DE	Compiling	Compile being performed.
	F00018	BIT	_INIT_RUN	Initializing	Initialization task being performed.
	F0001C	BIT	_PB1	Program code 1	Program code 1 selected.
	F0001D	BIT	_PB2	Program code 2	Program code 2 selected.
	F0001E	BIT	_CB1	Compile code 1	Compile code 1 selected.
	F0001F	BIT	_CB2	Compile code 2	Compile code 2 selected.

Device 1	Device 2	Туре	Variable	Function	Description		
F0002		DWORD	_CNF_ER	System error	Serious error in system reported.		
	F00020	BIT	_CPU_ER	CPU error	CPU configuration error found.		
	F00021	BIT	_IO_TYER	Module type error	Module type is not identical.		
	F00022	BIT	_IO_DEER90	Module installation error	Module is displaced.		
	F00023	BIT	_FUSE_ER	Fuse error	Fuse blown.		
	F00024	BIT	_IO_RWER	Module I/O error	Module I/O error found.		
	F00025	BIT	_IP_IFER	Module interface error	Error found in Special/communication module interface.		
	F00026	BIT	_ANNUM_ER	External equipment Error	Serious error detected in external equipment.		
	F00028	BIT	_BPRM_ER	Basic parameter	Basic parameter is abnormal.		
	F00029	BIT	_IOPRM_ER	IO parameter	IO configuration parameter abnormal.		
	F0002A	BIT	_SPPRM_ER	Special module parameter	Special module parameter abnormal.		
	F0002B	BIT	_CPPRM_ER	Communication module parameter	Communication module parameter abnormal.		
	F0002C	BIT	_PGM_ER	Program error	Program error found.		
	F0002D	BIT	_CODE_ER	Code error	Program code error found.		
	F0002E	BIT	_SWDT_ER	System watch-dog	System watch-dog active.		
	F0002F	BIT	_BASE_POWER_ ER	Power error	Base power abnormal.		
	F00030	BIT	_WDT_ER	Scan watch-dog	Scan watch-dog active.		
F0004		DWORD	_CNF_WAR	System warning	Slight error in system reported.		
	F00040	BIT	_RTC_ER	RTC error	RTC data abnormal.		
	F00041	BIT	_DBCK_ER	Back-up error	Data back-up error found.		
	F00042	BIT	_HBCK_ER	Restart error	Hot restart unavailable.		
	F00043	BIT	_ABSD_ER	Run error stop	Stopped due to abnormal run.		
	F00044	BIT	_TASK_ER	Task impact	Task being impacted.		
	F00045	BIT	_BAT_ER	Battery error	Battery status abnormal.		
	F00046	BIT	_ANNUM_WAR	External equipment error	Slight error detected in external equipment.		
	F00047	BIT	_LOG_FULL	Memory full	Log memory full		
	F00048	BIT	_HS_WAR1	HS link 1	HS link – parameter 1 error		
	F00049	BIT	_HS_WAR2	HS link 2	HS link – parameter 2 error		
	F0004A	BIT	_HS_WAR3	HS link 3	HS link – parameter 3 error		
	F0004B	BIT	_HS_WAR4	HS link 4	HS link – parameter 4 error		
	F0004C	BIT	_HS_WAR5	HS link 5	HS link – parameter 5 error		
	F0004D	BIT	_HS_WAR6	HS link 6	HS link – parameter 6 error		
	F0004E	BIT	_HS_WAR7	HS link 7	HS link – parameter 7 error		
	F0004F	BIT	_HS_WAR8	HS link 8	HS link – parameter 8 error		
	F00050	BIT	_HS_WAR9	HS link 9	HS link – parameter 9 error		

Appendix

Device 1	Device 2	Туре	Variable	Function	Description
	F00051	BIT	_HS_WAR10	HS link 10	HS link – parameter 10 error
	F00052	BIT	_HS_WAR11	HS link 11	HS link - parameter11 error
	F00053	BIT	_HS_WAR12	HS link 12	HS link - parameter12 error
	F00054	BIT	_P2P_WAR1	P2P parameter 1	P2P - parameter1 error
	F00055	BIT	_P2P_WAR2	P2P parameter 2	P2P – parameter2 error
	F00056	BIT	_P2P_WAR3	P2P parameter 3	P2P – parameter3 error
	F00057	BIT	_P2P_WAR4	P2P parameter 4	P2P – parameter4 error
	F00058	BIT	_P2P_WAR5	P2P parameter 5	P2P – parameter5 error
	F00059	BIT	_P2P_WAR6	P2P parameter 6	P2P – parameter6 error
	F0005A	BIT	_P2P_WAR7	P2P parameter 7	P2P – parameter7 error
	F0005B	BIT	_P2P_WAR8	P2P parameter 8	P2P – parameter8 error
	F0005C	BIT	_CONSTANT_ER	Fixed cycle error	Fixed cycle error
F0009		WORD	_USER_F	User contact point	Timer available for user.
	F00090	BIT	_T20MS	20ms	CLOCK of 20ms cycle.
	F00091	BIT	_T100MS	100ms	CLOCK of 100ms cycle.
	F00092	BIT	_T200MS	200ms	CLOCK of 200ms cycle.
	F00093	BIT	_T1S	1s	CLOCK of 1s cycle.
	F00094	BIT	_T2S	2s	CLOCK of 2s cycle.
	F00095	BIT	_T10S	10s	CLOCK of 10s cycle.
	F00096	BIT	_T20S	20s	CLOCK of 20s cycle.
	F00097	BIT	_T60S	60s	CLOCK of 60s cycle.
	F00099	BIT	_ON	Always ON	Bit always ON.
	F0009A	BIT	_OFF	Always OFF	Bit always OFF
	F0009B	BIT	_10N	1 scan ON	Bit only ON for the first scan.
	F0009C	BIT	_1OFF	1 scan OFF	Bit only OFF for the first scan.
	F0009D	BIT	_STOG	Reverse	Every scan reversed.
F0010		WORD	_USER_CLK	User CLOCK	CLOCK available to set by user.
	F00100	BIT	_USR_CLK0	Repeat specific scan	ON/OFF CLOCK 0 for specific scan
	F00101	BIT	_USR_CLK1	Repeat specific scan	ON/OFF CLOCK 1 for specific scan
	F00102	BIT	_USR_CLK2	Repeat specific scan	ON/OFF CLOCK 2 for specific scan
	F00103	BIT	_USR_CLK3	Repeat specific scan	ON/OFF CLOCK 3 for specific scan
	F00104	BIT	_USR_CLK4	Repeat specific scan	ON/OFF CLOCK 4 for specific scan
	F00105	BIT	_USR_CLK5	Repeat specific scan	ON/OFF CLOCK 5 for specific scan
	F00106	BIT	_USR_CLK6	Repeat specific scan	ON/OFF CLOCK 6 for specific scan
	F00107	BIT	_USR_CLK7	Repeat specific scan	ON/OFF CLOCK 7 for specific scan

Appendix

Device 1	Device 2	Туре	Variable	Function	Description
F0011		WORD	_LOGIC_RESUL T	Logic result	Logic result displayed.
	F00110	BIT	_LER	Calculation error	ON for 1 scan if calculation in error.
	F00111	BIT	_ZERO	Zero flag	ON if calculation result is 0.
	F00112	BIT	_CARRY	Carry flag	ON if Carry found during calculation.
	F00113	BIT	_ALL_OFF	Whole output OFF	ON if all output OFF
	F00115	BIT	_LER_LATCH	Calculation error latch	ON kept if calculation in error.
F0012		WORD	_CMP_RESULT	Compared result	Compared result displayed.
	F00120	BIT	_LT	LT flag	ON if "less than"
	F00121	BIT	_LTE	LTE flag	ON if "less than or equal"
	F00122	BIT	_EQU	EQU flag	ON if "equal"
	F00123	BIT	_GT	GT flag	ON if "greater than"
	F00124	BIT	_GTE	GTE flag	ON if "greater than or equal"
	F00125	BIT	_NEQ	NEQ flag	ON if "not equal"
F0013		WORD	_AC_F_CNT	Inspected power cut	Number of inspected power-cuts displayed.
F0014		WORD	_FALS_NUM	FALS No.	FALS No. displayed.
F0015		WORD	_PUTGET_ERR0	PUT/GET error 0	Main base PUT / GET error
F0016		WORD	_PUTGET_ERR1	PUT/GET error 1	Added base step 1 PUT / GET error
F0017		WORD	_PUTGET_ERR2	PUT/GET error 2	Added base step 2 PUT / GET error
F0018		WORD	_PUTGET_ERR3	PUT/GET error 3	Added base step 3 PUT / GET error
F0019		WORD	_PUTGET_ERR4	PUT/GET error 4	Added base step 4 PUT / GET error
F0020		WORD	_PUTGET_ERR5	PUT/GET error 5	Added base step 5 PUT / GET error
F0021		WORD	_PUTGET_ERR6	PUT/GET error 6	Added base step 6 PUT / GET error
F0022		WORD	_PUTGET_ERR7	PUT/GET error 7	Added base step 7 PUT / GET error
F0023		WORD	_PUTGET_NDR0	PUT/GET complete 0	Main base PUT / GET complete
F0024		WORD	_PUTGET_NDR1	PUT/GET complete 1	Added base step 1 PUT / GET complete
F0025		WORD	_PUTGET_NDR2	PUT/GET complete 2	Added base step 2 PUT / GET complete
F0026		WORD	_PUTGET_NDR3	PUT/GET complete 3	Added base step 3 PUT / GET complete
F0027		WORD	_PUTGET_NDR4	PUT/GET complete 4	Added base step 4 PUT / GET complete
F0028		WORD	_PUTGET_NDR5	PUT/GET complete 5	Added base step 5 PUT / GET complete
F0029		WORD	_PUTGET_NDR6	PUT/GET complete 6	Added base step 6 PUT / GET complete
F0030		WORD	_PUTGET_NDR7	PUT/GET complete 7	Added base step 7 PUT / GET complete
F0044		WORD	_CPU_TYPE	CPU type	Information on CPU type displayed.
F0045		WORD	_CPU_VER	CPU version	CPU version displayed.
F0046		DWORD	_OS_VER	OS version	OS version displayed.
F0048		DWORD	_OS_DATE	OS date	OS released date displayed.

Device 1	Device 2	Туре	Variable	Function	Description
F0050		WORD	_SCAN_MAX	Max. scan time	Max. scan time displayed
F0051		WORD _SCAN_MIN		Min. scan time	Min. scan time displayed
F0052		WORD	_SCAN_CUR	Present scan time	Present scan time displayed.
F0053		WORD	_MON_YEAR	Month / Year	PLC's time information (Month/Year)
F0054		WORD	_TIME_DAY	Hour / Date	PLC's time information (Hour/Date)
F0055		WORD	_SEC_MIN	Second / Minute	PLC's time information (Second/Minute)
F0056		WORD	_HUND_WK	100 years / Day	PLC's time information (100 years/Day)
F0057		WORD	_FPU_INFO	FPU calculation result	Floating decimal calculation result displayed.
	F00570	BIT	_FPU_LFLAG_I	Incorrect error latch	Latched if in incorrect error.
	F00571	BIT	_FPU_LFLAG_U	Underflow latch	Latched if underflow found.
	F00572	BIT	_FPU_LFLAG_O	Overflow latch	Latched if overflow found.
	F00573	BIT	_FPU_LFLAG_Z	Latch divided by 0	Latched if divided by 0.
	F00574	BIT	_FPU_LFLAG_V	Invalid calculation latch	Latched if invalid calculation.
	F0057A	BIT	_FPU_FLAG_I	Incorrect error	Reported if incorrect error found.
	F0057B	BIT	_FPU_FLAG_U	Underflow	Reported if underflow found.
	F0057C	BIT	_FPU_FLAG_O	Overflow	Reported if overflow found.
	F0057D	BIT	_FPU_FLAG_Z	Division by 0	Reported if divided by 0.
	F0057E BIT		_FPU_FLAG_V	Invalid calculation	Reported if calculation invalid.
	F0057F	BIT	_FPU_FLAG_E	Irregular value input	Reported if irregular value input.
F0058		DWORD	_ERR_STEP	Error step	Error step saved.
F0060		DWORD	_REF_COUNT	Refresh	Increased when module refresh executed.
F0062		DWORD	_REF_OK_CNT	Refresh OK	Increased if module refresh normal
F0064		DWORD	_REF_NG_CNT	Refresh NG	Increased if module refresh abnormal.
F0066		DWORD	_REF_LIM_CNT	Refresh LIMIT	Increased if module refresh abnormal (TIME OUT).
F0068		DWORD	_REF_ERR_CNT	Refresh ERROR	Increased if module refresh abnormal.
F0070		DWORD	_MOD_RD_ERR_ CNT	Module READ ERROR	Increased if module reads 1 word abnormally.
F0072		DWORD	_MOD_WR_ERR_ CNT	Module WRITE ERROR	Increased if module writes 1 word abnormally.
F0074		DWORD	_CA_CNT	Block service	Increased if module's block data serviced
F0076		DWORD	_CA_LIM_CNT	Block service LIMIT	Increased if module's block data service abnormal.
F0078		DWORD	_CA_ERR_CNT	Block service ERROR	Increased if module's block data service abnormal.
F0080		DWORD	_BUF_FULL_CNT	Buffer FULL	Increased if CPU's internal buffer is FULL.
F0082		DWORD	_PUT_CNT	PUT count	Increased if PUT executed.
F0084		DWORD	_GET_CNT	GET count	Increased if GET executed.
F0086		DWORD	_KEY	Present key	Local key's present status displayed.
F0088 DWORD _KEY_PR		_KEY_PREV	Previous key	Local key's previous status displayed.	

Device 1	Device 2	Туре	Variable	Function	Description
F0090		WORD	_IO_TYER_N	Discordant slot	Slot number with discordant module type displayed.
F0091		WORD	_IO_DEER_N	Displaced slot	Slot number with displaced module displayed.
F0092		WORD	_FUSE_ER_N	Fuse blown slot	Slot number with fuse blown displayed.
F0093		WORD	_IO_RWER_N	RW error slot	Slot number with module Read/Write error displayed.
F0094		WORD	_IP_IFER_N	IF error slot	Slot number with module interface error displayed.
F0096		WORD	_IO_TYER0	Module type 0 error	Main base module type error.
F0097		WORD	_IO_TYER1	Module type 1 error	Added base step 1 module type error.
F0098		WORD	_IO_TYER2	Module type 2 error	Added base step 2 module type error.
F0099		WORD	_IO_TYER3	Module type 3 error	Added base step 3 module type error.
F0100		WORD	_IO_TYER4	Module type 4 error	Added base step 4 module type error.
F0101		WORD	_IO_TYER5	Module type 5 error	Added base step 5 module type error
F0102		WORD	_IO_TYER6	Module type 6 error	Added base step 6 module type error
F0103		WORD	_IO_TYER7	Module type 7 error	Added base step 7 module type error
F0104		WORD	_IO_DEER0	Module installation 0 error	Main base module installation error
F0105		WORD	_IO_DEER1	Module installation 1 error	Added base step 1 module installation error
F0106		WORD	_IO_DEER2	Module installation 2 error	Added base step 2 module installation error
F0107		WORD	_IO_DEER3	Module installation 3 error	Added base step 3 module installation error
F0108		WORD	_IO_DEER4	Module installation 4 error	Added base step 4 module installation error
F0109		WORD	_IO_DEER5	Module installation 5 error	Added base step 5 module installation error
F0110		WORD	_IO_DEER6	Module installation 6 error	Added base step 6 module installation error
F0111		WORD	_IO_DEER7	Module installation 7 error	Added base step 7 module installation error
F0112		WORD	_FUSE_ER0	Fuse blown 0 error	Main base Fuse blown error
F0113		WORD	_FUSE_ER1	Fuse blown 1 error	Added base step 1 Fuse blown error
F0114		WORD	_FUSE_ER2	Fuse blown 2 error	Added base step 2 Fuse blown error
F0115		WORD	_FUSE_ER3	Fuse blown 3 error	Added base step 3 Fuse blown error
F0116		WORD	_FUSE_ER4	Fuse blown 4 error	Added base step 4 Fuse blown error
F0117		WORD	_FUSE_ER5	Fuse blown 5 error	Added base step 5 Fuse blown error
F0118		WORD	_FUSE_ER6	Fuse blown 6 error	Added base step 6 Fuse blown error
F0119		WORD	_FUSE_ER7	Fuse blown 7 error	Added base step 7 Fuse blown error
F0120		WORD	_IO_RWER0	Module RW 0 error	Main base module Read/Write error
F0121		WORD	_IO_RWER1	Module RW 1 error	Added base step 1 module Read/Write error
F0122		WORD	_IO_RWER2	Module RW 2 error	Added base step 2 module Read/Write error
F0123		WORD	_IO_RWER3	Module RW 3 error	Added base step 3 module Read/Write error
F0124		WORD	_IO_RWER4	Module RW 4 error	Added base step 4 module Read/Write error
F0125		WORD	_IO_RWER5	Module RW 5 error	Added base step 5 module Read/Write error
F0126		WORD	_IO_RWER6	Module RW 6 error	Added base step 6 module Read/Write error

Device 1	Device 2	Туре	Variable	Function	Description
F0127		WORD	_IO_RWER7	Module RW 7 error	Added base step 7 module Read/Write error
F0128	WORD _IO_IFER_1		_IO_IFER_0	Module IF 0 error	Main base module interface error
F0129			Module IF 1 error	Added base step 1 module interface error	
F0130		WORD _IO_IFER_2		Module IF 2 error	Added base step 2 module interface error
F0131		WORD	_IO_IFER_3	Module IF 3 error	Added base step 3 module interface error
F0132		WORD	_IO_IFER_4	Module IF 4 error	Added base step 4 module interface error
F0133		WORD	_IO_IFER_5	Module IF 5 error	Added base step 5 module interface error
F0134		WORD	_IO_IFER_6	Module IF 6 error	Added base step 6 module interface error
F0135		WORD	_IO_IFER_7	Module IF 7 error	Added base step 7 module interface error
F0136		WORD	_RTC_DATE	RTC date	RTC's present date
F0137		WORD	_RTC_WEEK	RTC day	RTC's present day of the week
F0138		DWOR D	_RTC_TOD	RTC time	RTC's present time (ms unit)
F0140		DWOR D	_AC_FAIL_CN T	Power-cut times	Power-cut times saved.
F0142		DWOR D	_ERR_HIS_C NT	Errors found	Number of found errors saved.
F0144		DWOR D	_MOD_HIS_C NT	Mode conversion times	Mode conversion times saved.
F0146		DWOR D	_SYS_HIS_C NT	History updated times	System's history updated times saved.
F0148		DWOR D	_LOG_ROTAT E	Log rotate	Log rotate information saved.
F0150	WORD	_BASE_INFO0	Slot information 0	Main base slot information	
F0151		WORD	_BASE_INFO1	Slot information 1	Added base step 1 slot information
F0152		WORD	_BASE_INFO2	Slot information 2	Added base step 2 slot information
F0153		WORD	_BASE_INFO3	Slot information 3	Added base step 3 slot information
F0154		WORD	_BASE_INFO4	Slot information 4	Added base step 4 slot information
F0155		WORD	_BASE_INFO5	Slot information 5	Added base step 5 slot information
F0156		WORD	_BASE_INFO6	Slot information 6	Added base step 6 slot information
F0157		WORD	_BASE_INFO7	Slot information 7	Added base step 7 slot information
F0158		WORD	_RBANK_NUM	Used block number	Presently used block number
F0159		WORD	_RBLOCK_ST ATE	Flash status	Flash block status
F0160		DWOR D	_RBLOCK_RD _FLAG	Flash Read	ON when reading Flash N block data.
F0162		DWOR D	 _RBLOCK_W R_FLAG	Flash Write	ON when writing Flash N block data.
F0164		DWOR D	RBLOCK_ER _FLAG	Flash error	Error found during Flash N block service.
F1024		WORD	_USER_WRIT E_F	Available contact	Contact point available in program
	F10240	BIT	_RTC_WR	RTC RW	Data Write & Read in RTC
	F10241	BIT	_SCAN_WR	Scan WR	Scan value initialization
	F10242	BIT	_CHK_ANC_E RR	Detect external serious error	Detection of serious error in external equipment requested.
	F10243	BIT	_CHK_ANC_ WAR	Detect external slight error	Detection of slight error in external equipment requested.

Appendix

Device 1	Device 2	Туре	Variable	Function	Description
F1025		WORD	_USER_STAU S_F	User contact point	User contact point
	F10250	BIT	_INIT_DONE	Initialization complete	Initialization complete displayed.
F1026		WORD	_ANC_ERR	External serious error information	Serious error information in external equipment displayed.
F1027		WORD	_ANC_WAR	External slight error information	Slight error information in external equipment displayed.
F1034		WORD	_MON_YEAR _DT	Month / Year	Time information data (Month/Year)
F1035		WORD	_TIME_DAY_ DT	Hour / Date	Time information data (Hour/Date)
F1036		WORD _SEC_MIN_E T _HUND_WK_ DT		Second / Minute	Time information data (Second/Minute)
F1037				100 years / Day	Time information data (100 years/Day)

A.1.2 Special register for data link

[Table 1] List of communication flags based on HS link No.

HS link No. 1 ~ 12

No.	Keyword	Туре	Detail	Description
L000000	_HS1_RLINK	Bit	HS link parameter No.1's all stations normally operated	Displays all stations normally operated as specified in HS link parameter, which will be On if 1.There is no RUN mode error in all stations specified in parameter 2.All data block is in normal communication as specified in parameter. 3.The parameter specified in each station itself is in normal communication. Run_link will be kept On if once On until stopped by link disenable.
L000001	_HS1_LTRBL	Bit	After _HS1RLINK is ON, abnormal status displayed	This flag will be On if the station specified in parameter and the data block's communication status are as described below with _HSmRLINK flag On,. 1. When the station specified in parameter is not in RUN mode, 2. When the station specified in parameter is in error, 3. When data block's communication status specified in parameter is unstable, The link trouble will be On if one of those conditions 1,2 and 3 Above occurs. And if such a condition is back to normal, it will be Off.
L000020 ~ L00009F	_HS1_STATE[k] (k=000~127)	Bit Array	HS link parameter No.1, Block No.k's general status displayed	Displays the general status of the communication information for the specified parameter's respective data blocks. HS1STATE[k]=HS1MOD[k]&_HS1TRX[k]&(~_HSmERR[k])
L000100 ~ L00017F	_HS1_MOD[k] (k=000~127)	Bit Array	HS link parameter No.1, Block No.k station's Run operation mode	Displays the operation mode of the station specified in parameter's data block k.
L000180 ~ L00025F	_HS1_TRX[k] (k=000~127)	Bit Array	Normal communication displayed with HS link parameter No.1, Block No.k station	Displays the communication status of parameter's data block k to check if normal as specified.
L000260 ~ L00033F	_HS1_ERR[k] (k=000~127)	Bit Array	HS link parameter No.1, Block No.k station's Run error mode	Displays the communication status of parameter's data block k to check for any error.
L000340 ~ L00041F	_HS1_SETBLOCK [k]	Bit Array	HS link parameter No.1, Block No.k setting displayed	Displays the setting status of parameter's data block k.

^{*} In the case of Dnet and Pnet, Block No.k stands for the station No. of the slave (in other words, it is station No.k).

Remark

HS link No.	L area address	Remarks
2	L000500~L00099F	Compared with HS link of 1 in [Table 1], other HS link station number's
3	L001000~L00149F	
4	L001500~L00199F	flag address will be simply calculated as follows;
5	L002000~L00249F	
6	L002500~L00299F	* Calculation formula:
7	L003000~L00349F	L area address = L000000 + 500 x (HS link No 1)
8	L003500~L00399F	, , , ,
9	L004000~L00449F	In order to use HS link flag for program and monitoring, use the flag
10	L004500~L00499F	map registered in XG5000 for convenient application
11	L005000~L00549F	

K as a block number is displayed through 8 words by 16 for 1 word for the information of 128 blocks from 000 to 127.

For example, block information of 16~31, 32~47, 48~63, 64~79, 80~95, 96~111, 112~127 will be displayed in L00011, L00012, L00013, L00014, L00015, L00016, L00017 from block 0 to block 15 for mode information ($_{\rm HS1MOD}$). Thus, the mode information of the block No. 55 will be displayed in L000137.

A.2 Terminology

General terms of DeviceNet I/F module are as described below for the suitable application of the product. Refer to DeviceNet specification for more details.

1) Fieldbus

Electric system to transmit small quantity of data between automatic devices fast and reliably so to execute a given task thoroughly.

2) Master Module

A module to send/receive and control data.

3) Slave Module

A module to respond to the data sent from the master module.

4) CAN (Controller Area Network) Protocol

Communication protocol designed compatible with dedicated automobile communication. CAN technology has been adopted in the device network. CAN is divided into 11-bit Identifier Field and Data Field which can transmit up to 8 bytes.

Identifier Field	RTR	Data Length	Data
		3.	

- Identifier Field : Area to set address (composed of 11 bits)
- Data: Field composed of actual data (up to 8 bytes can be transmitted)

5) Bus-Off

It produces an applicable error to abnormal network power.

6) ODVA (Open DeviceNet Vendor Association)

An association established to propagate DeviceNet communication widely.

7) Connection


As logic connection between master and slave which are connected through DeviceNet, it is used to keep and control all kinds of communication.

8) DeviceNet station No. (DeviceNet MAC ID)

Station No. of the communication module which has adopted DeviceNet standard. XGL_DMEA is specified through SyCon, and generally the station No. used for DeviceNet module is set by means of the switch installed on the front of the communication module. And this station No. is used as the station No. for all the services including HS link service.

9) Profile

It provides information on the device configuration data. (Printed data sheet, EDS; Electronic Data Sheet, etc.) It is named EDS in DeviceNet. It contains attributes of device and object address information of parameter. EDS's constitution is as shown below.



10) Packet

A data packet which is the basic unit used to transmit data through the network. With the header (Message identifier) attached in front, information on destination of the packet and other information necessary are added thereto.

11) CRC (Cyclic Redundancy Check)

As one of the error detection methods mostly used for synchronous transmission, it is also called as patrol signed type. CRC field of CAN protocol is displayed in 15- bit CRC and 'r' bit, composed of 1-bit CRC delimiter. If Rx node receives data frame, it deletes stuffing bits first and then checks for errors from SOF to data field through CRC. Since 15-bits CRC is suitable for the frame with bit counts less than 127 bits and CAN is of the max. 108-bit frame, it is appropriate to check for errors. If CRC divides transmitted value by multinomial expression created when transmitting and sends the value together attached to the back of message, the Rx side will divide the received data by the identical multinomial expression. And if the remainder is 'zero', it is regarded as No Error identified in this method.

12) Terminating resistance

Resistance used to adjust mutual impedance between Tx and Rx sides on the Physical Layer. Terminating resistance of DeviceNet is $121\Omega,1/4$ W,1%.

13) High-speed Link

A communication type used only between DeviceNet communication modules for the user to send/receive data at high speed, which execute communication with HS link parameters setting of XG-PD.

14) XG-PD (PLC Programming And Debugging Tool)

Software used for programming, downloading, run, stop, debugging applicably to PLC CPU module, where a diagnosis function is included to check the status of respective communication modules.

15) SyCon (System Configuration Tool)


Software used for system configuration through DeviceNet, where basic DeviceNet parameters can be set for master module and slave module, and setting details can be monitored through XG-PD as well.

16) Communication Type

4 types of DeviceNet communication are available (Poll, Bit-Strobe, COS and Cyclic). The communication types provided by respective slaves (remote I/O) may be different as such. DeviceNet can use the 4 communication types as mixed in a single network.


17) Poll

Master executes monitoring and data Tx/Rx for the respective slaves whenever scanned.




18) Bit Strobe

Master sends 1-bit output signal to respective slaves. Each slave which receives the output sign operates as specified. With data Tx/Rx minimized between master and slaves, the speed of the whole scan can be increased.




19) Cyclic

The slave set to cyclic sends the data of one time to the master for every cycle (max. 65535mS) specified.



20) COS (Change of State)

If any change occurs in the status of respective slaves, communication will be executed with the master. It is effective only for the slave monitoring the objects whose distance of status change is long. Data will be also sent to the master even if there is no change in the status with the max. COS distance of 65535ms specified in the slave.




21) MAC ID (Media Access Control Identifier)

Node Address on the DeviceNet network is defined as MAC ID, which uses 6 bits among 11 bits of CAN Identifier Field. MAC ID range of DeviceNet is available up to $0 \sim 63$.

22) CSMA/CD (Carrier Sense Multiple Access with Collision Detection)

Ethernet is of the structure configured to send the data after a client to send data checks if other computer in the network is being communicated and then no sign is found to be sent. If any collision occurs between data sent from various nodes at a time, CSMA/CD which monitors such a collision will keep the data for a specific time and then resend the sign to control the communication. For example, if a node is to use the network, cable status of the network will be checked first. At this time there will be no problem if any other node is not to use the network and there is no data in the cable, which allows normal execution free of any problem. However, if the network is tried to be used when other node is already using the network, there will be a collision in the cable. Once such a collision occurs, wait for the first node to complete the use and then retry after a while. The time necessary to wait after a collision occurs is mostly decided by the timer installed on the node. The time for respective nodes to wait shall be different from each other so to keep from another collision, which can be resolved with the time adjustment fixed inside the node, or by means of principal of random numbers applied. Use CSMA/CD to reduce the band width which is wasted during transmission of collided packets. CSMA/CD is as follows;

Access method	Description
CS (Carrier Sense)	Checks the network if being used.
MA (Multiple Access)	Available for any user if the network is empty.
CD (Collision Detection)	Checks for any collision while sending messages.



23) CSMA/NBA (Carrier Sense Multiple Access with Non-destructive Bitwise Arbitration)

Data Tx mechanism of CAN is similar to IEEE 802.3 CSMA/CD protocol. In other words, respective nodes check the status of the bus previously to sending the data, and then send the ready message if the bus is inactive. In CSMA/CD if two or more nodes send the messages at a time, the message will be collided and all lost. However, in CAN the message to be sent has 11-bit identifier allowing the message of high priority to be sent first. In other words, if two or more nodes send the messages at a time, the message of the highest priority (that is, the message with the lowest identifier value) will be sent while transmission of other messages of lower priority is stopped after identifiers are compared with each other bit by bit. As for the bus, '0' bit is superior to '1' bit. In other words, '0' bit is called as 'dominant' ('d' bit) and '1' as 'recessive' ('r' bit). Tx node monitors the bus whenever sending a bit. If a node sends 'r' bit and the monitoring result of the bus is 'd' bit, it means other node in the bus is sending the message of higher priority, thus the node will promptly stop transmitting the message to convert to Rx mode. The node which stops transmitting will monitor the status of the bus and then restart to transmit the message automatically if the bus is back to inactive status.

24) Reset

Communication module is initialized when error is occurred. It is executed [Online] – [Reset] menu in XG-PD. PLC is restarted.

25) Expected Packet Rate

Transmission value from slave module for I/O data exchange of master module

- a) Cyclic communication: Slave update the data by this setting value.
- b) COS communication: Slave can set the time of Watchdog timeout through this setting value.

26) Production inhibit time

Minimum delay time for updating of new data. It is not updated during this production inhibit time.

27) Fragmented Timeout

If I/O data is 8 bytes more than, master module wait until slave module give response within fragmented timeout setting.

A.3 Smart I/O Mode Setting in SyCon

Our company's slave module Smart I/O has built-in mode as shown below.

- 1) Standard mode
- 2) Quick start mode
- 3) Dummy mode


Each mode's characteristic is as shown below.


Mode type	Description
Standard mode	 ▶ After powered on master and slave model. - It takes 5~6 second to start the communication. - Default setting
Quick start mode	 If master and slave module support the Quick start mode function, it takes 1.5 second to start the communication. If only slave module supports the Quick start mode function, it takes 3~4 second to start the communication. (Setting address: Class-3, Instance-1, Attribute-10)
Dummy mode	 ▶ It makes a 1 word data size of slave input module additionally. - It can't write the data. (Setting address: Class-3, Instance-1, Attribute-40)

Mode setting is as shown below.

1) Mode setting


Select slave module to edit in editing window. Setting is available at menu bar.






A.4 External Dimensions

Unit: mm





Warranty

1. Terms of warranty

LSIS provides an 18-month warranty starting from the date of production.


2. Range of warranty

For problems within the terms of the warranty, LSIS will replace the entire PLC or repair the defective parts free of charge except for the following cases.

- (1) Problems caused by improper conditions, environment or treatment.
- (2) Problems caused by external devices.
- (3) Problems caused by the user remodeling or repairing the PLC.
- (4) Problems caused by improper use of the product.
- (5) Problems caused by circumstances where the expectations exceed that of the science and technology level when LSIS produced the product.
- (6) Problems caused by natural disaster.
- 3. This warranty is limited to the PLC itself only. It is not valid for the system which the PLC is attached to.

Environmental Policy

LSIS Co., Ltd supports and observes the environmental policy as below.





LSIS values every single customers.

Quality and service come first at LSIS.

Always at your service, standing for our customers.

http://eng.lsis.biz



10310000638

■ HEAD OFFICE

LS tower, Hogye-dong, Dongan-gu, Anyang-si, Gyeonggi-do 1026-6, Korea http://eng.lsis.biz

Tel: (82-2)2034-4870/Fax: 82-2-2034-4648 e-mail: cshwang@lsis.biz

■ LSIS Tokyo Office _ Tokyo, Japan

Address: 16FL. Higashi-Kan. Akasaka Twin Tower 17-22, Akasaka.Monato-ku Tokyo 107-8470. Japan

Tel: 81-3-3582-9128/Fax: 81-3-3582-2667 e-mail: jschuna@lsis.biz

■ LSIS (ME) FZE _ Dubai, U.A.E.

Address: Jafza View Tower Lob 19, Room 205 Along Sheikh Zayed Road Jebel Aali Free Zone Dubai, United Arab Emirates Tel: 971-4-886-5360/Fax: 971-4-886-5361 e-mail: jungyongl@lsis.biz

■ LSIS Shanghai Office _ Shanghai, China

Address: Room E-G. 12FL Hiamin Empire Plaza. No.726. West. Yan'an Road Shanghai 200050. P.R. China e-mail: liyong@lsis.com.cn Tel: 86-21-5237-9977(609)/Fax: 89-21-5237-7189

■ LSIS Beijing Office _ Beijing, China

Address: B-Tower 17FL. Beijing Global Trade Center B/D. No. 36.
East BeisanHuan-Road. DongCheng-District. Beijing 100013. P.R. China
Tel: 86-10-5825-6027(666)/Fax: 86-10-5825-6028 e-mail: xunmi@lsis.com.cn

■ LSIS Guangzhou Office _ Guangzhou, China

Address: Room 1403.14FL. New Poly Tower. 2 Zhongshan Liu Road.Guangzhou.P.R China

Tel : 86-20-8328-6754/Fax : 86-20-8326-6287 e-mail : <u>chenxs@lsis.com.cn</u>

■ LSIS Chengdu Office _ Chengdu, China

Address: 12FL. Guodong Buiding. No.52 Jindun Road Chengdu.610041. P.R. China

Tel : 86-28-8612-9151(9226)/Fax : 86-28-8612-9236 e-mail : comysb@lsis.biz

■ LSIS Qingdao Office _ Qingdao, China

Address : YinHe Bldg. 402 Room No. 2P Shandong Road,

Qingdao-City, Shandong-province 266071, P.R. China

Tel: 86-532-8501-6068/Fax: 86-532-8501-6057 e-mail: wangzy@lsis.com.cn

■ LSIS Europe B.V., Netherlands

Address: 1st. Floor, Tupolevlaan 48, 1119NZ, Schiphol-Rijk, The Netherlands Tel: +31 (0)20 654 1420/Fax: +31 (0)20 654 1429 e-mail: junshickp@lsis.biz

■ Wuxi LSIS Co., Ltd _ Wuxi, China

Address: 102-A. National High & New Tech Industrial Development Area. Wuxi. Jiangsu. 214028. P.R. China

Tel: 86-510-8534-6666/Fax: 86-510-8534-4078 e-mail: caidx@lsis.com.cn

■ Dalian LSIS Co., Ltd. _ Dalian, China

Address: No. 15. Liaohexi 3-Road. Economic and Technical Development zone. Dalian 116600. China

Tel: 86-411-273-7777/Fax: 86-411-8730-7560 e-mail: cuibx@lsis.com.cn

X LSIS constantly endeavors to improve its product so that information in this manual is subject to change without notice.

X and X and X are a constantly endeavors to improve its product so that information in this manual is subject to change without notice.

X and X are a constantly endeavors to improve its product so that information in this manual is subject to change without notice.

X and X are a constantly endeavors to improve its product so that information in this manual is subject to change without notice.

X and X are a constantly endeavors to improve its product so that information in this manual is subject to change without notice.

X and X are a constantly endeavors to improve its product so that information in this manual is subject to change without notice.

X and X are a constantly endeavors to improve its product so that information in this manual is subject to change without notice.

X and X are a constantly endeavors to improve its product so that it is not information in this manual is subject to change without notice.

X and X are a constantly endeavors to improve its product so that it is not information in the constantly endeavors.

X are a constantly endeavors to improve its product so that it is not information in the constantly endeavors.

X and X are a constantly endeavors to improve its product so the constantly endeavors to improve its product so the constantly endeavors.

X and X are a constantly endeavors to improve its product so the constantly endeavors to improve its produ

© LSIS Co., Ltd 2011 All Rights Reserved.